



# Revised Fact Sheet

Public Comment Start Date:

Public Comment Expiration Date:

Technical Contact: Brian Nickel  
206-553-6251  
800-424-4372, ext. 6251 (within Alaska, Idaho, Oregon and Washington)  
Nickel.Brian@epa.gov

## **Proposed Reissuance of a National Pollutant Discharge Elimination System (NPDES) Permit to Discharge Pollutants Pursuant to the Provisions of the Clean Water Act (CWA)**

### **City of Post Falls Wastewater Treatment Plant**

#### **EPA Proposes To Reissue NPDES Permit**

EPA proposes to reissue an NPDES permit to the facility referenced above. The draft permit places conditions on the discharge of pollutants from the wastewater treatment plant to waters of the United States. In order to ensure protection of water quality and human health, the permit places limits on the types and amounts of pollutants that can be discharged from the facility.

This Fact Sheet includes:

- information on public comment, public hearing, and appeal procedures
- a listing of proposed effluent limitations and other conditions for the facility
- a map and description of the discharge location
- technical material supporting the conditions in the permit

#### **401 Certification**

EPA is requesting that the Idaho Department of Environmental Quality certify the NPDES permit for this facility, under section 401 of the Clean Water Act. Comments regarding the certification should be directed to:

Regional Administrator  
Idaho Department of Environmental Quality  
2110 Ironwood Pkwy  
Coeur d'Alene, ID 83814

**Public Comment**

Pursuant to 40 CFR 124.14(c), at this time, EPA is only accepting comments on aspects of the draft permit that are different from those in the draft permit that was issued for public comment on February 16, 2007. These are as follows:

- The final effluent limitations for total phosphorus, five day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia, copper, pH, and chlorine have been revised (see the revised draft permit at Table 1, Part I.B).
- Effluent limits and monitoring requirements for chlorine now apply only when chlorine is used for disinfection or elsewhere in the treatment process.
- The schedule of compliance for new water quality-based CBOD<sub>5</sub> limits has been deleted (see the revised draft permit at Part I.C).
- The interim effluent limitations for phosphorus (which apply during the term of the compliance schedule) have been revised (see the revised draft permit at Part I.D).
- Surface water monitoring requirements have been changed (see the revised draft permit at Part I.F).
- The draft permit no longer contains a compliance evaluation level for total residual chlorine effluent limits.
- The draft permit now requires more frequent effluent monitoring for whole effluent toxicity and total residual chlorine relative to the 2007 draft permit (see the revised draft permit at Parts I.B and I.E).
- In addition to more frequent monitoring, the draft permit includes additional requirements for whole effluent toxicity testing (e.g. accelerated testing, toxicity reduction evaluation) to ensure consistency with EPA guidance (see the revised draft permit at Part I.E).
- The permit now includes influent and effluent monitoring requirements for 2,3,7,8 tetrachlorodibenzo-p-dioxin (2,3,7,8 TCDD) (see the revised draft permit at Parts I.B and II.H).
- The phosphorus management plan requirements have been changed (see the revised draft permit at Part II.B).
- The permit now includes best management practices requirements intended to reduce the discharge of polychlorinated biphenyls (PCBs) and 2,3,7,8 TCDD (see the revised draft permit at Part II.H).

Persons wishing to comment on the tentative determinations contained in the draft permit may do so in writing to the above address or by e-mail to “Nickel.Brian@epa.gov” within 60 days of the date of this public notice. Comments must be received within the 60 day period to be considered in the formulation of final determinations regarding the applications. All comments should include the name, address and telephone number of the commenter and a concise statement of the exact basis of any comment and the relevant facts upon which it is based. All written comments and requests should be submitted to EPA at the above address to the attention of the Director, Office of Water and Watersheds.

**Workshop and Public Hearing**

A workshop and public hearing will be held.

Date:

Time: Workshop from 5:00 PM to 7:00 PM  
Public hearing from 7:00 PM to 9:00 PM

Place: Lake City Senior Center  
1916 North Lakewood Drive  
Coeur d'Alene, ID 83814

Comments made on the draft permits at the public hearing will become part of the administrative record for the permits, along with any written comments received.

After the Public Notice expires, and all comments have been considered, EPA's regional Director for the Office of Water will make a final decision regarding permit issuance. If no substantive comments are received, the proposed conditions in the draft permit will become final, and the permit will become effective upon issuance. If comments are received, EPA will address the comments and issue the permit. The permit will become effective 30 days after the issuance date, unless an appeal is submitted to the Environmental Appeals Board within 30 days of the service of notice of the final permit decision.

**Documents are Available for Review**

The draft NPDES permit and related documents can be reviewed or obtained by visiting or contacting EPA's Regional Office in Seattle between 8:30 a.m. and 4:00 p.m., Monday through Friday at the address below. The draft permits, fact sheet, and other information can also be found by visiting the Region 10 NPDES website at "<http://epa.gov/r10earth/waterpermits.htm>."

United States Environmental Protection Agency  
Region 10  
1200 Sixth Avenue  
Suite 900 M/S OWW-130  
Seattle, Washington 98101  
(206) 553-6251 or  
Toll Free 1-800-424-4372 (within Alaska, Idaho, Oregon and Washington)

The fact sheet and draft permits are also available at:

Idaho Department of Environmental Quality  
Coeur d'Alene Regional Office  
2110 Ironwood Pkwy  
Coeur d'Alene, ID 83814  
208-799-4370  
1-877-541-3304

Post Falls Library  
821 North Spokane Street  
Post Falls, ID 83854  
208-773-1506

Hayden Lake Library  
8385 North Government Way  
Hayden, ID 83835  
208-772-5612, ext. 11

U.S. Environmental Protection Agency  
Idaho Operations Office  
1435 North Orchard  
Boise, ID 83706  
208-378-5748

U.S. Environmental Protection Agency  
Coeur d'Alene Field Office  
1910 Northwest Blvd., Suite 208  
Coeur d'Alene, ID 83814  
208-665-0458

Washington State Department of Ecology  
Eastern Regional Office  
4601 North Monroe Street, Suite 202  
Spokane, WA 99205-1295  
509-329-3400

## Table of Contents

<b>Acronyms .....</b>	<b>7</b>
<b>I. Applicant .....</b>	<b>9</b>
<b>II. Facility Information .....</b>	<b>10</b>
<b>III. Receiving Water .....</b>	<b>10</b>
A. Low Flow Conditions .....	10
B. Water Quality Standards .....	11
C. Water Quality Limited Segment .....	12
<b>IV. Effluent Limitations .....</b>	<b>18</b>
A. Basis for Effluent Limitations .....	18
B. Proposed Effluent Limitations .....	18
C. Schedules of Compliance .....	20
D. Deletion of Total Residual Chlorine Compliance Evaluation Level .....	21
E. Basis for Substitution of Different Pollutant Parameters for 1999 Effluent Limits .....	21
F. Basis for Less-Stringent Mass Limits for TSS, Copper and Winter CBOD <sub>5</sub> and Ammonia .....	21
G. Basis for Less-Stringent Effluent Limits for Total Residual Chlorine .....	22
<b>V. Monitoring Requirements .....</b>	<b>23</b>
A. Basis for Effluent and Surface Water Monitoring .....	23
B. Effluent Monitoring .....	23
C. Surface Water Monitoring .....	26
<b>VI. Sludge (Biosolids) Requirements .....</b>	<b>27</b>
<b>VII. Other Permit Conditions .....</b>	<b>28</b>
A. Quality Assurance Plan .....	28
B. Phosphorus Management Plan .....	28
C. Pretreatment .....	28
D. Sanitary Sewer Overflows and Proper Operation and Maintenance of the Collection System .....	28
E. Additional Permit Provisions .....	29
<b>VIII. Other Legal Requirements .....</b>	<b>30</b>
A. Endangered Species Act and Essential Fish Habitat .....	30
B. State/Tribal Certification .....	30
C. Permit Expiration .....	30
<b>IX. References .....</b>	<b>30</b>
<b>Appendix A: Facility Map .....</b>	<b>A-1</b>

**Appendix B: Water Quality-based Effluent Limits for Phosphorus, Ammonia and Carbonaceous Biochemical Oxygen Demand Necessary to Meet Water Quality Criteria for Dissolved Oxygen in Washington and Nutrients in Idaho ..... B-1**

A.	Overview .....	1
B.	Requirement to Meet Washington's Water Quality Standards .....	1
C.	Applicable Water Quality Standards and Status of Waters .....	2
D.	Modeling Supporting the Permit Limits.....	4
E.	Translating the Modeled Loads to Effluent Limits .....	8
F.	Effect of the Proposed Effluent Limits.....	23
G.	References .....	26

**Appendix C: General Basis for Effluent Limits..... C-1**

A.	Technology-Based Effluent Limits .....	1
B.	Water Quality-based Effluent Limits .....	2
C.	Facility-Specific Limits .....	4
D.	Summary of Limits and Bases.....	7

**Appendix D: Reasonable Potential Calculations ..... D-1**

A.	Mass Balance.....	1
B.	Maximum Projected Effluent Concentration .....	3
C.	Results .....	5
D.	References .....	5

**Appendix E: WQBEL Calculations – Acute and Chronic Numeric Aquatic Life CriteriaE-1**

A.	Calculate the Wasteload Allocations (WLAs) .....	1
B.	Basis for Expressing Effluent Limits for Toxic Parameters as Average Monthly and Maximum Daily Limits .....	1
C.	Calculating the Average Monthly and Maximum Daily Effluent Limits .....	2
D.	Results .....	2

**Appendix F: Effluent Limit Calculations for pH.....F-1****Appendix G: Compliance Schedules and Interim Limits for New Water Quality-based Effluent Limits ..... G-1**

A.	Overview .....	1
B.	Immediate Achievability .....	1
C.	As Soon as Possible.....	5
D.	References .....	5

**Acronyms**

1Q10	1 day, 10 year low flow
7Q10	7 day, 10 year low flow
30B3	Biologically-based design flow intended to ensure an excursion frequency of less than once every three years, for a 30-day average flow.
AML	Average Monthly Limit
BOD <sub>5</sub>	Biochemical oxygen demand, five-day
°C	Degrees Celsius
CFR	Code of Federal Regulations
CV	Coefficient of Variation
CWA	Clean Water Act
DMR	Discharge Monitoring Report
DO	Dissolved oxygen
EFH	Essential Fish Habitat
EPA	U.S. Environmental Protection Agency
ESA	Endangered Species Act
IDEQ	Idaho Department of Environmental Quality
lbs/day	Pounds per day
LTA	Long Term Average
mg/L	Milligrams per liter
ml	milliliters
ML	Minimum Level
µg/L	Micrograms per liter
mgd	Million gallons per day
MDL	Maximum Daily Limit
N	Nitrogen
NOAA	National Oceanic and Atmospheric Administration
NPDES	National Pollutant Discharge Elimination System
OW	Office of Water
O&M	Operations and maintenance
POTW	Publicly owned treatment works
QAP	Quality assurance plan

RP	Reasonable Potential
RPM	Reasonable Potential Multiplier
RWC	Receiving Water Concentration
s.u.	Standard Units
TMDL	Total Maximum Daily Load
TSD	Technical Support Document for Water Quality-based Toxics Control (EPA/505/2-90-001)
TSS	Total suspended solids
USFWS	U.S. Fish and Wildlife Service
USGS	United States Geological Survey
WLA	Wasteload allocation
WQBEL	Water quality-based effluent limit
WWTP	Wastewater treatment plant



## I. Applicant

This fact sheet provides information on the draft NPDES permit for the following entity:

City of Post Falls  
NPDES Permit # ID-002585-2

Mailing Address  
408 North Spokane Street  
Post Falls, ID 83854

Physical Address:  
1720 West Seltice Way  
Post Falls, ID 83854

Contact:  
Terry Werner, Public Services Director

Federal regulations state that comments filed during a reopened comment period shall be limited to the substantial new questions that caused its reopening, and that the public notice under 40 CFR 124.10 shall define the scope of the reopening (40 CFR 124.14). As stated in the public notice, EPA is only accepting comments on permit conditions that are different from those proposed in the draft permit that was issued for public review and comment on February 16, 2007.

EPA is making significant changes to the draft permit as it was proposed in February 2007. These changes result from comments made during the initial public comment period, the availability of the final *Spokane River and Lake Spokane Dissolved Oxygen Total Maximum Daily Load: Water Quality Improvement Report*, hereinafter referred to as the Spokane DO TMDL (Ecology 2010), more recent effluent and receiving water quality and quantity data, updated computer modeling of the impact of the discharge, and EPA guidance documents. To allow the public an opportunity to comment on all of these changes, EPA has decided to reopen the public comment period to accept comments on these specific changes. The changed conditions are as follows:

- The final effluent limitations for total phosphorus, five day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia, copper, pH, and chlorine have been revised (see the revised draft permit at Table 1, Part I.B).
- Effluent limits and monitoring requirements for chlorine now apply only when chlorine is used for disinfection or elsewhere in the treatment process (see the revised draft permit at Table 1, Part I.B).
- The schedule of compliance for new water quality-based CBOD<sub>5</sub> limits has been deleted (see the revised draft permit at Part I.C).
- The interim effluent limitations for phosphorus (which apply during the term of the compliance schedule) have been revised (see the revised draft permit at Part I.D).
- Surface water monitoring requirements have been changed (see the revised draft permit at Part I.F).

- The draft permit no longer contains a compliance evaluation level for total residual chlorine effluent limits.
- The draft permit now requires more frequent effluent monitoring for whole effluent toxicity and total residual chlorine relative to the 2007 draft permit (see the revised draft permit at Parts I.B and I.E).
- In addition to more frequent monitoring, the draft permit includes additional requirements for whole effluent toxicity testing (e.g. accelerated testing, toxicity reduction evaluation) to ensure consistency with EPA guidance (see the revised draft permit at Part I.E).
- The permit now includes influent and effluent monitoring requirements for 2,3,7,8 tetrachlorodibenzo-p-dioxin (2,3,7,8 TCDD) (see the revised draft permit at Parts I.B and II.H).
- The phosphorus management plan requirements have been changed (see the revised draft permit at Part II.B).
- The permit now includes best management practices requirements intended to reduce the discharge of polychlorinated biphenyls (PCBs) and 2,3,7,8 TCDD (see the revised draft permit at Part II.H).

## II. Facility Information

In general, facility information is provided in the fact sheet for the initial public comment period dated February 16, 2007. The POTW has been expanded to a design flow of 5.0 mgd since the time the 2007 draft permit was issued. A map of the treatment plant and discharge location is provided in Appendix A.

## III. Receiving Water

This facility discharges to the Spokane River in Kootenai County, Idaho. The outfall is located approximately 0.2 miles downstream of the Post Falls Dam and approximately 4.5 miles upstream of the Washington line at river mile 100.5.

### A. Low Flow Conditions

The *Technical Support Document for Water Quality-Based Toxics Control* (hereinafter referred to as the TSD) (EPA 1991) and the Idaho Water Quality Standards (WQS) recommend the flow conditions for use in calculating water quality-based effluent limits (WQBELs) using steady-state modeling. The TSD and the Idaho WQS state that WQBELs intended to protect aquatic life uses should be based on the lowest seven-day average flow rate expected to occur once every ten years (7Q10) for chronic criteria and the lowest one-day average flow rate expected to occur once every ten years (1Q10) for acute criteria. However, because the chronic criterion for ammonia is a 30-day average concentration not to be exceeded more than once every three years, EPA has used the 30Q10 for the chronic ammonia criterion instead of the 7Q10. In the 2007 draft permit, the 30B3 flow rate was generally paired with the chronic ammonia criterion. However, the latest version of the software used to calculate low flow conditions (DFLOW version 3.1b) does not allow the calculation of the 30B3 flow rate on a seasonal basis, so the 30Q10 flow rate has been used instead of the 30B3.

EPA has re-calculated the low flow values, using more recent river flow data, since the close of the 2007 public comment period. The values in Table 1 were calculated using data from the Post Falls gauge (USGS station # 12419000), using a period of record of 1978-2008.

The seasons used to calculate the critical low flows have also been changed relative to the 2007 draft permit and fact sheet in order to match the seasonal calculations used to develop the 1999 permit. This allows a direct comparison to determine if the effluent limits in the 1999 permit remain adequate to protect water quality in the Spokane River.

From July – September, the critical low flow rates based on historical data are less than the minimum flow rates specified in the Federal Energy Regulatory Commission (FERC) license for the Post Falls Dam. EPA has used the FERC minimum flows for effluent limit calculations, in lieu of the historical low flows.

<b>Table 1: Seasonal Low Flows in the Spokane River</b>			
<b>Season</b>	<b>1Q10 (CFS)</b>	<b>7Q10 (CFS)</b>	<b>30Q10 (CFS)</b>
October – June	890	1030	1270
July – Sep. (based on historical data)	248	292	363
July – Sep. (FERC license)	500		

## **B. Water Quality Standards**

Section 301(b)(1)(C) of the Clean Water Act (Act) requires that NPDES permits contain effluent limits more stringent than technology-based limits when necessary to meet water quality standards. A State's water quality standards are composed of use classifications, numeric and/or narrative water quality criteria, and an anti-degradation policy. The use classification system designates the beneficial uses (such as cold water aquatic life, contact recreation, etc.) that each water body is expected to achieve. The numeric and/or narrative water quality criteria are the criteria deemed necessary by the State to support the beneficial use classification of each water body. The anti-degradation policy represents a three-tiered approach to maintain and protect various levels of water quality and uses.

### ***Idaho Water Quality Standards***

At the point of discharge, the Spokane River is protected for the following designated uses (IDAPA 58.01.02.110.12):

- cold water aquatic life habitat
- salmonid spawning
- primary contact recreation
- domestic water supply

In addition, the Idaho Water Quality Standards state that all waters of the State of Idaho are protected for industrial and agricultural water supply (Section 100.03.b and c.), wildlife habitats (100.04) and aesthetics (100.05).

Primary contact recreation is defined by the Idaho Water Quality Standards as “water quality appropriate for prolonged and intimate contact by humans or for recreational activities when the ingestion of small quantities of water is likely to occur. Such activities include, but are not restricted to swimming, water skiing, or skin diving.”

The Spokane River also has site-specific criteria for ammonia (IDAPA 58.01.02.283). The site-specific ammonia criteria are identical to the statewide ammonia criteria for waters designated for cold water aquatic life when early life stages of fish are present (IDAPA 58.01.02.250.02.d.).

### ***Idaho's Antidegradation Policy***

The EPA is required under Section 301(b)(1)(C) of the Clean Water Act (CWA) and implementing regulations (40 CFR 122.4(d) and 122.44(d)) to establish conditions in NPDES permits that ensure compliance with State water quality standards, including antidegradation requirements. The antidegradation analysis is conducted as part of the State's CWA Section 401 certification.

### ***Washington Water Quality Standards***

The City of Post Falls wastewater treatment plant outfall is located approximately 4.5 river miles upstream from the Washington border. Federal regulations require that NPDES permits include conditions necessary to ensure compliance with the water quality requirements of all affected States (40 CFR 122.4(d), 40 CFR 122.44(d)(4), see also CWA Section 401(a)(2)). Therefore it is necessary to determine if the discharge has the reasonable potential to cause or contribute to excursions above Washington's water quality standards, in addition to Idaho's water quality standards. If the discharge has the reasonable potential to cause or contribute to excursions above Washington's water quality standards, effluent limits must be established, which ensure compliance with Washington's water quality standards, in addition to Idaho's water quality standards. EPA has determined that the discharge has the reasonable potential to cause or contribute to excursions above Washington's water quality standards for dissolved oxygen. See Appendix B for a complete discussion of the effluent limits based upon Washington's water quality standards.

### **C. Water Quality Limited Segment**

A water quality limited segment is any waterbody, or definable portion of a waterbody, where it is known that water quality does not meet applicable water quality standards, and/or is not expected to meet applicable water quality standards. In accordance with section 303(d) of the Clean Water Act, States must identify waters not achieving water quality standards in spite of the application of technology-based controls in National Pollutant Discharge Elimination System (NPDES) permits for point sources. Such waterbodies are known as water quality limited segments (WQLSs), and the list of such waterbodies is called the "303(d) list." Once a water body is identified as a WQLS, the States are required under the Clean Water Act to develop a total maximum daily load (TMDL). A TMDL is a determination of the amount of a pollutant, or property of a pollutant, from point, nonpoint, and natural background sources (including a margin of safety) that may be discharged to a water body without causing the water body to exceed the water quality criterion for that pollutant. The Spokane River flows through Idaho and Washington, and various segments of the river are water quality limited in both States.

### ***Total Phosphorus (Idaho)***

The Spokane River is listed in Idaho's 2010 303(d)/305(b) integrated report as not attaining or not being expected to attain water quality standards for total phosphorus. As explained in

Appendix B, the water quality-based effluent limits for total phosphorus in the draft permit will ensure compliance with Idaho's narrative water quality criterion for nutrients (IDAPA 58.01.02.200.06).

### ***Metals (Idaho)***

The segment of the Spokane River to which the City of Post Falls discharges was listed in Idaho's 1998 303(d) list as not attaining or not expected to meet State water quality standards for cadmium, lead, and zinc. In August of 2000, EPA approved a TMDL submitted by the State of Idaho for metals in the Coeur d'Alene River Basin, which included this segment of the Spokane River. However, in 2003, the Idaho Supreme Court determined that the TMDL was invalid. Therefore, the Spokane River remains listed in the 2010 303(d)/305(b) integrated report as being impaired for cadmium, lead, and zinc.

Even though the Idaho Supreme Court invalidated the Coeur d'Alene River Basin TMDL under State law, EPA must nonetheless evaluate whether water quality-based effluent limits are necessary for cadmium, lead, and zinc under CWA regulations at 40 CFR 122.44(d)(1)(i – iii), and assure that any such effluent limits are derived from, and comply with, applicable water quality standards (40 CFR 122.44(d)(1)(vii)(A)).

EPA established "criteria end-of-pipe" water quality-based effluent limits for lead and zinc in the 1999 permit. Since the Spokane River is 303(d) listed for cadmium, lead, and zinc, the river has no assimilative capacity to dilute these metals in an effluent. Therefore, no mixing zone may be authorized for cadmium, lead, or zinc.

A reasonable potential analysis, which did not consider the dilution of the effluent in the receiving water, showed that the discharge does not have the reasonable potential to cause or contribute to excursions above water quality standards for cadmium; therefore the draft permit does not contain effluent limits for cadmium.

The numeric values of the acute and chronic water quality criteria for cadmium, lead, zinc, and certain other metals are dependent upon the hardness of the water. For the criteria end-of-pipe reasonable potential and effluent limit calculations for cadmium, lead and zinc, the effluent hardness was used to calculate the water quality criteria. As long as the concentrations of cadmium, lead, and zinc in the effluent are below the water quality criteria (calculated at the effluent hardness) the effluent will not cause or contribute to an in-stream excursion above water quality standards.

The lead and zinc effluent limits in this 2012 revised draft permit are identical to those in the 2007 draft permit and the 1999 final permit. The lead and zinc loading limits must be at least as stringent as those in the 1999 permit (even though the POTW's design flow has increased) in order to ensure compliance with IDAPA 58.01.02.055.04, as stipulated in the State of Idaho's draft Clean Water Act Section 401 certification for this draft permit. IDAPA 58.01.02.055.04 requires that the total load of pollutants causing water quality limited listings must remain constant or decrease within the watershed until a TMDL or equivalent process is completed. EPA is specifically requesting public comments on the effluent limits for lead and zinc.

***Temperature (Idaho)***

The fact sheet dated February 16, 2007 stated that the Spokane River was listed in Idaho's 2002/2004 303(d)/305(b) integrated report as being impaired for temperature. The Spokane River is not listed for temperature in Idaho's 2010 integrated report. The 1999 permit did not include effluent limits for temperature. When developing the 2007 draft permit, EPA determined that the discharge did not have the reasonable potential to cause or contribute to excursions above water quality standards for temperature, and no temperature effluent limits were proposed in the 2007 draft permit. In developing the revised draft permit, EPA re-evaluated the need for effluent limits for temperature and has once again determined that the discharge does not have the reasonable potential to cause or contribute to excursions above water quality standards for temperature; therefore, no effluent limits are proposed for temperature in the revised draft permit.

The finding that the discharge does not have the reasonable potential to cause or contribute to excursions above Idaho's water quality standards for temperature has not changed since the 2007 draft permit was issued for public review and is not one of the substantial new questions that caused the reopening of the comment period.

***Dissolved Oxygen (Washington)***

In the fact sheets dated February 16, 2007 for the Cities of Coeur d'Alene and Post Falls and the Hayden Area Regional Sewer Board, EPA made a finding that the discharges of oxygen-demanding pollution from those sources have the reasonable potential to cause or contribute to excursions below Washington's water quality criterion for dissolved oxygen in Lake Spokane. The draft permits issued for public review and comment in February 2007 therefore included water quality-based effluent limits for phosphorus, CBOD<sub>5</sub>, and ammonia, which were intended to ensure compliance with Washington's water quality criterion for dissolved oxygen in lakes and reservoirs, as required by federal regulations (40 CFR 122.4(d)). The "reasonable potential" finding (which determines whether or not water quality-based effluent limits based upon Washington water quality standards are necessary for oxygen-demanding pollutants, see 40 CFR 122.44(d)(1)(i – iii)) remains valid.

However, comments received during the public comment period regarding the calculation of phosphorus, ammonia, and CBOD<sub>5</sub> limits led EPA to re-evaluate the effluent limits for these parameters. Commenters stated that the effluent limits should be calculated based on the cumulative dissolved oxygen impact of all human actions. Furthermore, in February 2008, after the close of the initial public comment period, EPA approved revisions to Washington's water quality standards, which made those revised standards effective for Clean Water Act purposes, including NPDES permits (40 CFR 131.21). Among the changes to Washington's water quality standards was a change to the water quality criterion for dissolved oxygen (DO) in lakes and reservoirs. At the time of the initial public comment period in 2007, the water quality criterion for DO in lakes and reservoirs that was in effect for Clean Water Act purposes read "no measurable decrease from natural conditions" (WAC 173-201A-030(5)(c)(ii), 1997). The revised standard reads "for lakes, human actions considered cumulatively may not decrease the dissolved oxygen concentration more than 0.2 mg/L below natural conditions" (WAC 173-201A-200(1)(d)(ii), 2006). The significant differences between the old and current criteria are that the allowable amount of DO decrease relative to the natural condition is now numeric (0.2 mg/L)

instead of a narrative statement (“no measurable decrease”), and the current criterion states that this allowable DO decrease is based on the cumulative impact of human actions.

In addition, the State of Washington has prepared and EPA has approved the *Spokane River and Lake Spokane Dissolved Oxygen Total Maximum Daily Load: Water Quality Improvement Report*, dated February 2010 and hereinafter referred to as the Spokane DO TMDL. In the Spokane DO TMDL, the State of Washington made specific assumptions about the amounts of oxygen-demanding pollution that will be discharged by sources in Idaho.

In light of the comments received during the initial comment period, the changes to the Washington water quality standards, and the availability of the Spokane DO TMDL, EPA has determined that the effluent limits for phosphorus, ammonia and CBOD<sub>5</sub> proposed in the 2007 draft permit should be changed in order to ensure compliance with Washington’s dissolved oxygen criterion for lakes and reservoirs.

Therefore, EPA has proposed revised water quality-based effluent limitations for phosphorus, ammonia, and five-day carbonaceous biochemical oxygen demand in the City of Post Falls draft permit. These effluent limits ensure that the level of water quality to be achieved by limits on point sources is derived from and complies with all applicable water quality standards (40 CFR 122.44(d)(1)(vii)(A)). The effluent limits are based on the cumulative impact of all human actions that affect dissolved oxygen concentrations in Lake Spokane. See Appendix B for a complete explanation of the water quality-based phosphorus, ammonia, and CBOD<sub>5</sub> effluent limits in the draft permit, that are based on Washington water quality standards for dissolved oxygen. EPA is specifically requesting public comments on all of the water quality-based effluent limits in the draft permit that are derived from Washington’s water quality standards.

### ***Metals (Washington)***

The segment of the Spokane River immediately downstream from the State line is listed in Washington’s 2008 303(d)/305(b) integrated report for cadmium, lead, and zinc. The listing category for these metals is 4A, which means that a TMDL has been prepared for these pollutants. The *Spokane River Dissolved Metals Total Maximum Daily Load* (Butkus and Merrill, 1999) was approved by EPA on August 25, 1999.

As stated in the fact sheet dated February 16, 2007, EPA has determined that the City’s discharge does not have the reasonable potential to cause or contribute to excursions above Washington’s water quality standards for cadmium, lead or zinc. The finding that the discharge does not have the reasonable potential to cause or contribute to excursions above Washington’s water quality standards for cadmium, lead, or zinc has not changed since the 2007 draft permit was issued for public review and is not one of the substantial new questions that caused the reopening of the comment period.

### ***Temperature (Washington)***

The segment of the Spokane River immediately downstream from the State line is listed in Washington’s 2008 303(d)/305(b) integrated report as not attaining or not being expected to attain water quality standards for temperature. As explained in Appendix B, EPA has determined that the discharges from Idaho point sources do not have the reasonable potential to cause or contribute to excursions above Washington’s water quality standards for temperature.

The finding that the discharge does not have the reasonable potential to cause or contribute to excursions above Washington's water quality standards for temperature has not changed since the 2007 draft permit was issued for public review and is not one of the substantial new questions that caused the reopening of the comment period.

#### ***Total Polychlorinated Biphenyls and Dioxin (Washington)***

The Spokane River is listed in Washington's 2008 303(d)/305(b) integrated report as not attaining or not being expected to attain water quality standards for total polychlorinated biphenyls (PCBs), due to elevated concentrations in fish tissue. The Spokane Tribe of Indians has EPA-approved water quality standards for its waters, which are downstream of the Long Lake Dam, and data from lower Lake Spokane indicate that the Tribe's water quality criterion for PCBs (in the water column) is not being attained (Serdar et al. 2011). The Spokane River is also listed in Washington's 2008 303(d)/305(b) integrated report as not attaining or not being expected to attain water quality standards for 2,3,7,8 tetrachlorodibenzo-p-dioxin (2,3,7,8 TCDD), due to elevated concentrations in fish tissue.

As stated in the fact sheet dated February 16, 2007, currently, there are insufficient data to determine if the discharges from point sources to the Spokane River in Idaho have the reasonable potential to cause or contribute to excursions above water quality standards for PCBs in waters of the State of Washington or the Spokane Tribe of Indians. There are also insufficient data to determine if the discharges from point sources to the Spokane River in Idaho have the reasonable potential to cause or contribute to excursions above water quality standards for 2,3,7,8 TCDD. Therefore, no numeric water quality-based effluent limits are proposed for PCBs or 2,3,7,8 TCDD in the draft permit.

The draft permits for the Cities of Post Falls and Coeur d'Alene and the Hayden Area Regional Sewer Board propose bi-monthly influent and quarterly effluent and surface water column monitoring upstream and downstream of the outfall for total PCBs, and quarterly influent and effluent monitoring for 2,3,7,8 TCDD. The influent and effluent monitoring frequencies are the same as required in the State of Washington's permit for the Liberty Lake Sewer and Water District (WA0045144). These data will be used to determine if the discharges have the reasonable potential to cause or contribute to excursions above water quality standards for PCBs in waters of the State of Idaho, the State of Washington or the Spokane Tribe of Indians. The permit specifies the analytical methods and maximum detection limits that must be used for analysis of total PCBs and 2,3,7,8 TCDD, in order to ensure that the data collected are meaningful.

The permits do not propose surface water monitoring for 2,3,7,8 TCDD because the detection limit of EPA Method 1613B (4.4 picograms per liter) is much greater than the water quality criterion for 2,3,7,8 TCDD that is currently in effect for Clean Water Act purposes in Idaho (0.013 picograms per liter) (EPA 1994). Thus, surface water monitoring for 2,3,7,8 TCDD using Method 1613B would be unlikely to yield meaningful data.

The NPDES permits for municipal separate storm sewer systems that discharge pollutants to the Spokane River in Idaho also include monitoring requirements for total PCBs.

The average total PCB concentration at the Washington – Idaho border is 106 picograms per liter (pg/L) (Serdar et al. 2011). This concentration is 38% less than Washington's and Idaho's water



quality criteria for total PCBs (170 pg/L) that are in effect under the CWA.<sup>1</sup> The Spokane Tribe's water quality criterion for PCBs is 3.37 pg/L. Furthermore, in 1999, the USGS performed sampling of fish tissue in Idaho at station #12419000 (Spokane River near Post Falls, Idaho). The concentration of PCBs measured in fish collected from this station was 270 µg/kg (USGS 2003). The 170 pg/L Clean Water Act effective water column criterion for PCBs in Idaho and Washington corresponds to a fish tissue concentration of 5.3 µg/kg.<sup>2,3</sup> Since the measured fish tissue concentration is greater than the fish tissue that corresponds to the criterion, the measured fish tissue concentration indicates elevated levels of PCBs.

PCBs have been detected in effluent from POTWs discharging to the Spokane River in the State of Washington (i.e., the City of Spokane and the Liberty Lake Sewer and Water District) as well as other POTWs in Washington State operated by the Cities of Medical Lake, Okanogan, College Place, Walla Walla, Pullman, Colfax, Albion, Bremerton, Tacoma, and Everett, and King and Pierce counties. Effluent concentrations of total PCBs at these 14 facilities (a total of 34 samples) ranged from 46.6 to 39,785 pg/L with a median concentration of 810 pg/L, and 82% of the results (28 out of 34) were greater than Idaho's and Washington's Clean Water Act effective water quality criterion of 170 pg/L (Coots and Deligeannis 2010; Ecology 2010; Johnson et al. 2004; Serdar 2003; Serdar et al. 2011; personal communication with Richard Koch, Ecology, September 8, 2011). Design flows of these POTWs range from 0.54 mgd (Okanogan) to 215 mgd (King County West Point). PCBs were also detected in 96% of samples (69 out of 72) of effluents collected from 18 POTWs discharging to the Yakima River in central Washington State in 2007 and 2008. The median effluent concentration of total PCBs at these 18 POTWs was 370 pg/L and the maximum concentration was 7,400 pg/L; 82% of the samples (59 out of 72) exceeded Washington's water quality criterion of 170 pg/L (Johnson et al. 2010).

The fact that the average concentration of PCBs at the State line is more than half the value of the water quality criterion that is in effect under the Clean Water Act in Washington and Idaho and that high concentrations of PCBs have been measured in fish tissue in the Spokane River in Idaho, in addition to the frequent detection of PCBs at concentrations above water quality criteria in other POTWs as described above, suggests that pollution sources in Idaho may be contributing to exceedances of water quality criteria for PCBs.

Moreover, 2,3,7,8 TCDD has been detected in the effluent from the City of Medical Lake wastewater treatment plant (1.85 mgd design flow) in Washington State at a concentration of 0.56 pg/L, which is 43 times the criterion that is in effect for Clean Water Act purposes in both Idaho and Washington, which is 0.013 pg/L (Coots and Deligeannis 2010).<sup>4</sup> According to data obtained from EPA's Envirofacts database, 2,3,7,8 TCDD has also been detected in the effluents

---

<sup>1</sup> Idaho's PCB water quality criterion that is in effect under State law is 64 pg/L. However, EPA has not yet taken an approval or disapproval action on this criterion and therefore it is not in effect for Clean Water Act purposes. (See 40 CFR 131.21(c)(2))

<sup>2</sup> The PCB water quality criterion that is in effect under State law in Idaho is equivalent to a fish tissue concentration of 2.0 µg/kg.

<sup>3</sup> The bioconcentration factor (BCF) is the ratio of a substance's concentration in tissue versus its concentration in water, in situations where the food chain is not exposed or contaminated. For non-metabolized substances, it represents equilibrium partitioning between water and organisms. The BCF for PCBs is 31,200 L/kg (EPA 2002). Multiplying the BCF by the water column criterion yields the equivalent fish tissue concentration.

<sup>4</sup> Idaho's 2,3,7,8 TCDD water quality criterion that is in effect under State law is 0.005 pg/L. However, EPA has not yet taken an approval or disapproval action on this criterion and therefore it is not in effect for Clean Water Act purposes. (See 40 CFR 131.21(c)(2))

from seven POTWs in Arizona, California and Florida. The median concentration of 2,3,7,8 TCDD among 36 samples from those seven POTWs was 1.05 pg/L, which is 81 times the criterion (Nickel 2011). Design flows of the Arizona, California, and Florida POTWs with 2,3,7,8 TCDD effluent data range from 2.2 to 37 mgd.

Studies in the 1990s found mixtures of dioxins and furans in POTW effluents of 0.27 to 0.81 toxicity equivalents (TEQ)<sup>5</sup> (EPA 2006). Potential sources of dioxins and furans in POTW discharges include laundry wastewater, particularly from clothing dyes and pigments containing dioxins and furans and from cotton treated with pentachlorophenol (which is used in some developing countries), runoff from streets with high traffic density, and industrial sources such as metal manufacturing (EPA 2006). This information suggests that point sources in Idaho may also be contributing to excursions above water quality standards for 2,3,7,8 TCDD in waters of the State of Washington.

Therefore, although it is not known at this time which specific sources contribute PCBs or 2,3,7,8 TCDD to the Spokane River in Idaho, EPA believes that, similar to POTWs in the State of Washington and elsewhere, the Idaho POTWs may be discharging PCBs and 2,3,7,8 TCDD, and that best management practices (BMP) requirements to control or abate the discharge of PCBs and 2,3,7,8 TCDD are reasonably necessary to carry out the purposes and intent of the Clean Water Act. Due to the lack of data, it is infeasible to calculate numeric water quality-based effluent limits for PCBs and 2,3,7,8 TCDD at this time. Therefore, the draft permit includes BMP requirements for PCBs and 2,3,7,8 TCDD, consistent with 40 CFR 122.44(k)(3) and (4). The BMP requirements are in Part II.H of the draft permit.

EPA is specifically requesting comments on the monitoring and BMP requirements for PCBs and 2,3,7,8 TCDD.

## **IV. Effluent Limitations**

### **A. Basis for Effluent Limitations**

In general, the Clean Water Act (Act) requires that the effluent limits for a particular pollutant be the more stringent of either technology-based limits or water quality-based limits. Technology-based limits are set according to the level of treatment that is achievable using available technology. A water quality-based effluent limit is designed to ensure that the water quality standards of a waterbody are being met and may be more stringent than technology-based effluent limits. The bases for the proposed effluent limits in the draft permit are provided in Appendices B, C, D, E, F, and G.

### **B. Proposed Effluent Limitations**

Below are the proposed effluent limits that are in the draft permit (see Part I.B).

1. Removal Requirements for CBOD<sub>5</sub> and TSS: The monthly average effluent concentration must not exceed 15 percent of the monthly average influent concentration. Percent removal of CBOD<sub>5</sub> and TSS must be reported on the

---

<sup>5</sup> The TEQ procedure translates the complex mixture of dioxins and furans characteristic of environmental releases into an equivalent toxicity concentration of 2,3,7,8-tetrachlorodibenzo-p-dioxin (2,3,7,8-TCDD), the most toxic member of this class of compounds.

Discharge Monitoring Reports (DMRs). For each parameter, the monthly average percent removal must be calculated from the arithmetic mean of the influent values and the arithmetic mean of the effluent values for that month. Influent and effluent samples must be taken over approximately the same time period.

2. The permittee must not discharge floating, suspended or submerged matter of any kind in concentrations causing nuisance or objectionable conditions or that may impair designated beneficial uses.

Table 2 (below) presents the proposed final seasonal average, average monthly, average weekly, maximum daily, and instantaneous maximum effluent limits. Limits that are different from those in the 2007 draft permit are shown in italic type. EPA is specifically requesting public comments on all of these revised effluent limits.

<b>Table 2: Proposed Final Effluent Limits</b>				
Parameter	Units	Effluent Limits		
		Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit
<b>Five-Day Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>)</b> November – January	mg/L	25	40	—
	lb/day	1043	1668	—
	% removal	85% (minimum)	—	—
<b>CBOD<sub>5</sub></b> February – October	mg/L	25	40	—
	lb/day	334	534	—
	% removal	85% (minimum)	—	—
<b>Total Suspended Solids (TSS)</b>	mg/L	30	45	—
	lb/day	1251	1877	—
	% removal	85% (minimum)	—	—
<b>pH</b> (October – June)	s.u.	6.3 – 9.0		
<b>pH</b> (July – September)	s.u.	6.4 – 9.0		
<b>Total Phosphorus as P<sup>2</sup></b> (Feb. – Oct.)	lb/day	Seasonal Average Limit: 3.19 lb/day		
<b>E. Coli Bacteria</b>	#/100 ml	126 (geometric mean)	—	406 (single sample maximum)
<b>Total Residual Chlorine</b> (July – September if chlorine is used for disinfection or elsewhere in the treatment process)	µg/L	127	—	294
	lb/day	5.30	—	13.6
<b>Total Residual Chlorine</b> (October – June if chlorine is used for disinfection or elsewhere in the treatment process)	µg/L	244	—	565
	lb/day	10.2	—	23.6
<b>Total Ammonia as N</b> (February – June and October)	lb/day	334	528	—
<b>Total Ammonia as N</b> (July – September)	mg/L	8.00	12.7	—
	lb/day	334	528	—
<b>Total Ammonia as N</b> (November – February)	mg/L	25.4	—	91.7
	lb/day	1059	—	3824
<b>Copper</b> (July – September)	µg/L	13.8	—	27.7
	lb/day	0.58	—	1.16

<b>Table 2: Proposed Final Effluent Limits</b>				
<b>Parameter</b>	<b>Units</b>	<b>Effluent Limits</b>		
		<b>Average Monthly Limit</b>	<b>Average Weekly Limit</b>	<b>Maximum Daily Limit</b>
<b>Lead</b>	µg/L	2.05	—	3.79
	lb/day	0.059	—	0.110
<b>Zinc</b>	µg/L	84.3	—	115
	lb/day	2.45	—	3.34
Notes: 1. No single sample may exceed 406 organisms per 100 ml (instantaneous maximum limit). 2. These effluent limits are subject to a compliance schedule. Until the final effluent limits become effective, the permittee must comply with interim effluent limitations (see Table 3, below). 3. The monthly geometric mean concentration of E. coli must not exceed 126 organisms per 100 ml.				

### C. Schedules of Compliance

Schedules of compliance are authorized by federal NPDES regulations at 40 CFR 122.47 and by Section 400.03 of the Idaho Water Quality Standards. The Idaho water quality standards allow for compliance schedules “when new limitations are in the permit for the first time.” The federal regulation allows schedules of compliance “when appropriate,” and requires that such schedules require compliance as soon as possible. When the compliance schedule is longer than 1 year, federal regulations require that the schedule shall set forth interim requirements and the dates for their achievement. The time between the interim dates shall generally not exceed 1 year, and when the time necessary to complete any interim requirement is more than one year, the schedule shall require reports on progress toward completion of these interim requirements. Federal regulations also require that interim effluent limits be at least as stringent as the final limits in the previous permit (40 CFR 122.44(l)(1)).

EPA policy states that, in order to grant a compliance schedule, a permitting authority must make a reasonable finding that the permittee cannot comply with the effluent limit immediately upon the effective date of the final permit (see memorandum from Jim Hanlon to Alexis Strauss, May 10, 2007). Some of the proposed effluent limits for phosphorus, CBOD<sub>5</sub>, ammonia, and chlorine are new limits that are in the permit for the first time. However, EPA has determined that the permittee can, in fact, comply with all of these effluent limits, except phosphorus, immediately upon the effective date of the final permit, as explained in Appendix G.

Therefore, a compliance schedule is proposed only for phosphorus. The compliance schedule includes interim effluent limitations, as shown in Table 3, below. The interim phosphorus limits retain the 70% removal effluent limit from the 1999 permit, in order to ensure compliance with 40 CFR 122.44(l)(1). In order to ensure compliance with 40 CFR 122.45(f), which requires that effluent limits are expressed in terms of mass, EPA has calculated interim mass effluent limits for phosphorus, which apply in addition to the removal rate limits. The interim monthly average mass limit is equal to the mass loading of phosphorus that the permittee could have discharged while maintaining compliance with the removal rate effluent limit in the 1999 permit. In order to ensure compliance with 40 CFR 122.45(d)(2), which requires that effluent limits for POTWs shall be expressed as average weekly and average monthly discharge limitations, EPA has

included an interim average weekly mass limit for phosphorus, which is equal to the average monthly limit multiplied by 1.6. This accounts for effluent variability within a month.

The compliance schedules are based on the draft Clean Water Act Section 401 certification provided to EPA by the Idaho Department of Environmental Quality. The final permit will contain compliance schedules consistent with the State of Idaho's final Clean Water Act Section 401 certification, which may differ from the draft certification. EPA believes that the compliance schedule proposed for phosphorus complies with the regulatory requirement that compliance be achieved "as soon as possible" (40 CFR 122.47(a)(1)), as explained in Appendix G.

Because the compliance schedules are authorized by the State of Idaho in the Section 401 certification, comments on the compliance schedules should be directed to the Idaho Department of Environmental Quality at the address listed on the front page of this Fact Sheet and in the public notice of the availability of this draft permit, in addition to EPA.

<b>Table 3: Interim Effluent Limits</b>			
<b>Parameter</b>	<b>Units</b>	<b>Effluent Limits</b>	
		<b>Average Monthly Limit</b>	<b>Average Weekly Limit</b>
<b>Total Phosphorus as P</b> February – October	lb/day	68.5	110
	% rem.	70% (min.)	—

#### **D. Deletion of Total Residual Chlorine Compliance Evaluation Level**

The 2007 draft permit contained a compliance evaluation level of 100 µg/L (0.1 mg/L) for total residual chlorine. This compliance evaluation level was based on the minimum level (ML) of chlorine analytical methods that are no longer approved for use in NPDES permitting (see 40 CFR 136). The proposed effluent limits for total residual chlorine are greater than the concentrations that can be quantified using approved analytical methods for chlorine. Therefore, the compliance evaluation level has been deleted.

#### **E. Basis for Substitution of Different Pollutant Parameters for 1999 Effluent Limits**

The draft permit proposes effluent limits for E. coli in lieu of the 1999 permit's fecal coliform limits and also proposes CBOD<sub>5</sub> limits in lieu of BOD<sub>5</sub> limits. The bases for these changes are explained in the fact sheet dated February 16, 2007. The proposed substitution of E. coli for the 1999 permit's fecal coliform limits is unchanged from the draft permit issued for public review in 2007 and is not one of the substantial new questions that caused EPA to reopen the public comment period and is included here for the purpose of providing background context. Therefore, EPA is not requesting comments on the E. coli limits at this time.

#### **F. Basis for Less-Stringent Mass Limits for TSS, Copper and Winter CBOD<sub>5</sub> and Ammonia**

The increase in the mass limits for CBOD<sub>5</sub> (for November – January) and TSS are not subject to the anti-backsliding provisions of the Act (Section 402(o)(1)), because these technology-based limits are based on the "secondary treatment" requirement of Sections 301(b)(1)(B) and

304(d)(1) of the Act. The anti-backsliding provisions of the Clean Water Act apply to effluent limits established based on Sections 301(b)(1)(C), 303(d) or (e), or 402(a)(1)(B) (i.e., water quality based effluent limits and effluent limits based on best professional judgment). Effluent limits for POTWs must be calculated based on the design flow of the POTW (40 CFR 122.45(b)(1)) and the design flow of the POTW has increased from 3.48 mgd to 5.0 mgd since the time the prior permit was issued (1999). The increased mass limits for TSS and winter CBOD<sub>5</sub> ensure compliance with the State of Idaho's antidegradation policy. EPA is specifically requesting comments on the revised mass limits for winter CBOD<sub>5</sub> and for TSS.

Similarly, EPA has revised the mass limits for copper and the winter mass limits (November – January) for ammonia. These effluent limits were water quality-based effluent limits. Therefore, unlike the TSS and CBOD<sub>5</sub> limits discussed above, they are subject to the anti-backsliding provisions of the Clean Water Act. However, an exception is applicable in this case.

As explained in Appendix C, EPA has determined that the prior permit's concentration limits for copper and winter ammonia are stringent enough to ensure compliance with water quality standards for these parameters, even though the design flow of the POTW has increased from 3.48 mgd to 5.0 mgd. The increased design flow of the POTW is a material and substantial alteration or addition to the facility, which provides an exception to the general prohibition on backsliding in the Clean Water Act (Section 402(o)(2)(A)). Effluent limits for POTWs must be calculated based on the design flow of the POTW (40 CFR 122.45(b)(1)) and the design flow of the POTW has increased from 3.48 mgd to 5.0 mgd since the time the prior permit was issued (1999). Therefore, the mass limits for copper and winter ammonia have been re-calculated based on the increased design flow of the POTW.

#### **G. Basis for Less-Stringent Effluent Limits for Total Residual Chlorine**

At the time the 1999 permit was issued, the Post Falls facility used chlorine for disinfection. The facility now uses ultraviolet disinfection, but retains the ability to disinfect with chlorine as a backup. The switch from chlorine to ultraviolet disinfection is a material and substantial alteration or addition to the facility, which provides an exception to the general prohibition on backsliding in the Clean Water Act (Section 402(o)(2)(A)).

Although the Post Falls facility uses ultraviolet disinfection, the City has continued to monitor the effluent for chlorine. The effluent data indicate that the facility has the reasonable potential to cause or contribute to excursions above water quality standards for chlorine when the facility uses chlorine for disinfection or elsewhere in the treatment process. Therefore, the draft permit proposes water quality-based effluent limits for chlorine, under these circumstances.

Effluent data indicate that the facility does not have the reasonable potential to cause or contribute to excursions above water quality standards for chlorine if chlorine is not used in the treatment process. Therefore, no effluent limits or monitoring requirements are proposed for total residual chlorine when chlorine is not used in the treatment process.

The concentration and mass limits are less stringent than those in the prior permit. The effluent limits have been recalculated based on current water quality criteria, the authorized mixing zone, and the variability of the effluent concentrations observed when chlorine is used in the treatment process. As explained above, the switch from chlorine to ultraviolet disinfection and the increased design flow of the POTW are material and substantial alterations or additions to the

permitted facility, which provide an exception to the general prohibition on backsliding in the Clean Water Act (Section 402(o)(2)(A)).

EPA is specifically requesting comments on the changes to the effluent limitations for chlorine.

## **V. Monitoring Requirements**

### **A. Basis for Effluent and Surface Water Monitoring**

Section 308 of the CWA and the federal regulation 40 CFR 122.44(i) require monitoring in permits to determine compliance with effluent limitations. Monitoring may also be required to gather effluent and surface water data to determine if additional effluent limitations are required and/or to monitor effluent impacts on receiving water quality. The permittee is responsible for conducting the monitoring and for reporting results on Discharge Monitoring Reports (DMRs) or on the application for renewal, as appropriate, to the U.S. Environmental Protection Agency (EPA).

### **B. Effluent Monitoring**

In general, the basis for the effluent monitoring requirements in the draft permit was explained in the fact sheet dated February 16, 2007. Some changes to the effluent monitoring requirements are proposed, as explained below. The proposed effluent monitoring requirements are shown in Table 4, below.

#### ***Whole Effluent Toxicity***

The whole effluent toxicity (WET) testing requirements have been expanded to include a requirement to prepare an initial investigation toxicity reduction evaluation (TRE) plan, a requirement to conduct accelerated testing in the event of an excursion above a trigger value (which is based on the dilution of the effluent in the receiving water at the edge of a mixing zone encompassing 25% of the critical low flow of the receiving water) and a requirement to conduct a TRE if an additional excursion above the trigger occurs during accelerated testing. These requirements are consistent with the recommendations of the EPA *Regions 9 and 10 Guidance for Implementing Whole Effluent Toxicity Testing Programs* (EPA 1996b). These requirements were included in the 1999 permit, but were omitted from the 2007 draft permit.

In addition, the revised draft permit proposes a semi-annual (twice per year) monitoring frequency for WET, which is the same as the 1999 permit. The 2007 draft permit had proposed annual (once per year) monitoring for WET, however, there is no basis to reduce the WET monitoring frequency relative to the 1999 permit. Finally, in the draft permit, EPA is proposing to require the permittee to use three organisms for toxicity testing (a fish, an invertebrate, and a plant), consistent with the recommendations of the *Regions 9 and 10 Guidance for Implementing Whole Effluent Toxicity Testing Programs* (Page 2-18) and the *Technical Support Document for Water Quality-based Toxics Control* (Section 3.3.3). The 2007 draft permit only required testing of a fish and an invertebrate.

EPA is specifically requesting public comment on the revised WET testing requirements.

***Total Residual Chlorine***

In the 2007 draft permit, EPA had proposed to reduce the monitoring frequency for total residual chlorine from twice per day in the 1999 permit to once per month. As stated in the 2007 fact sheet (Page 20), this was done because the permittee generally does not use chlorine for disinfection.

However, as explained above, under the heading “Basis for Less-Stringent Effluent Limits for Total Residual Chlorine,” EPA has determined that effluent limits and monitoring requirements for chlorine should be conditional, based on whether or not the facility uses chlorine in the treatment process. Effluent monitoring for total residual chlorine is not required when chlorine is not used in the treatment process.

When chlorine is used in the treatment process, effluent limits are proposed in the draft permit, and monitoring is required. EPA has adapted the *Interim Guidance for Performance - Based Reductions of NPDES Permit Monitoring Frequencies* (interim monitoring reduction guidance) to determine the appropriate monitoring frequency. The required sampling frequency for total residual chlorine, in the prior permit, was twice per day. The interim monitoring reduction guidance does not provide recommended reduced monitoring frequencies for a baseline frequency of twice per day, so EPA has adapted the recommendations for a baseline monitoring frequency of twice per week to the daily monitoring frequency. The average effluent concentration of total residual chlorine, at times when the facility uses chlorine in the treatment process, is 91 µg/L, which is 72% of the proposed average monthly effluent limit for July – September, and 37% of the proposed average monthly effluent limit for October – June. If the prior permit’s required monitoring frequency had been twice per week, the ratio for the July – September effluent limit would not support a reduction in the monitoring frequency. However, the October – June ratio would support a reduction.

Therefore, at times when the chlorine is used in the treatment process, EPA proposes a monitoring frequency for chlorine of twice per day for July – September (the same as the prior permit), and once per day for October – June. EPA is specifically requesting comments on the revised monitoring requirements for chlorine.

***Permit Application Monitoring***

The draft permit proposes to require all of the monitoring that would be necessary to produce a complete application for renewal of this permit. Effluent monitoring required by Part B.6 of application form 2A (which is required of all facilities with a design flow greater than or equal to 0.1 mgd) is required at a frequency of quarterly for oil and grease and total dissolved solids, and monthly for nitrogen and phosphorus species that are not subject to effluent limits. More frequent monitoring is required for nitrogen and phosphorus species because these are nutrients, and nutrients are known to contribute to water quality impairments in this watershed (i.e., for dissolved oxygen in the State of Washington and total phosphorus in the State of Idaho).

Effluent monitoring required by Part D of application form 2A, which is not required by other provisions of this permit, is required at the minimum frequency required by the application (three samples over the term of the permit).



Table 4: Effluent Monitoring Requirements				
Parameter	Unit	Sample Location	Sample Frequency	Sample Type
Flow	mgd	Effluent	Continuous	Recording
CBOD <sub>5</sub> November – January	mg/L	Influent and Effluent	1/week	24-hour composite
	lbs/day	Influent and Effluent		calculation <sup>1</sup>
	% Removal	--	1/month	calculation <sup>2</sup>
	CBOD <sub>5</sub> February – October	mg/L	Influent and Effluent	3/week
lbs/day		Influent and Effluent	calculation <sup>1</sup>	
% Removal		--	1/month	calculation <sup>2</sup>
TSS		mg/L	Influent and Effluent	1/week
	lbs/day	Influent and Effluent	calculation <sup>1</sup>	
	% Removal	--	1/month	calculation <sup>2</sup>
	pH	standard units	Effluent	5/week
E. Coli Bacteria	#/100 ml	Effluent	5/month	grab
Total Residual Chlorine (July – September if chlorine is used for disinfection or elsewhere in the treatment process)	µg/L	Effluent	2/day	grab
	lb/day			calculation
Total Residual Chlorine (October – June if chlorine is used for disinfection or elsewhere in the treatment process)	µg/L	Effluent	1/day	grab
	lb/day			calculation
Total Residual Chlorine (If chlorine is not used for disinfection or elsewhere in the treatment process)	No monitoring or reporting required.			
Chlorine Usage	lb/day	Chlorine contact chamber	1/day	Measure
Total Ammonia as N (Feb. – Oct.)	mg/L	Effluent	3/week	24-hour composite
	lb/day			calculation
Total Ammonia as N (Nov. – Jan.)	mg/L	Effluent	1/month	24-hour composite
	lb/day			calculation
Total Phosphorus February – October	µg/L	Effluent	3/week	24-hour composite
	lb/day			calculation
Total Phosphorus November – January	µg/L	Effluent	1/week	24-hour composite
Copper July – September	µg/L	Effluent	1/month	24-hour composite
	lb/day			calculation
Copper October - June	µg/L	Effluent	1/month	24-hour composite
Lead	µg/L	Effluent	1/month	24-hour composite
	lb/day			calculation
Zinc	µg/L	Effluent	1/month	24-hour composite
	lb/day			calculation
Temperature	°C	Effluent	5/week	grab
Cadmium	µg/L	Effluent	1/month	24-hour composite
Silver	µg/L	Effluent	1/month	24-hour composite
Alkalinity	mg/L as CaCO <sub>3</sub>	Effluent	1/month	24-hour composite
Hardness	mg/L as CaCO <sub>3</sub>	Effluent	1/month	24-hour composite

**Table 4: Effluent Monitoring Requirements**

Parameter	Unit	Sample Location	Sample Frequency	Sample Type
Oil and Grease	mg/L	Effluent	1/quarter	grab
Total Dissolved Solids	mg/L	Effluent	1/quarter	24-hour composite
Total Polychlorinated Biphenyls	pg/L	Influent and Effluent	1/2 months	24-hour composite
2,3,7,8 Tetrachlorodibenzo-p-dioxin	pg/L	Influent and Effluent	1/quarter	24-hour composite
Orthophosphate as P	mg/L	Effluent	1/month	24-hour composite
Total Kjeldahl Nitrogen	mg/L	Effluent	1/month	24-hour composite
Nitrate plus Nitrite Nitrogen	mg/L	Effluent	1/month	24-hour composite
Dissolved Oxygen	mg/L	Effluent	1/month	grab
NPDES Application Form 2A Expanded Effluent Testing	---	Effluent	3x/5years	---
Whole Effluent Toxicity	TU <sub>c</sub>	Effluent	2/year	24-hour composite

## Notes:

1. Maximum daily loading is calculated by multiplying the concentration in mg/L by the average daily flow in mgd and a conversion factor of 8.34.
2. Percent removal is calculated using the following equation:  

$$(\text{average monthly influent} - \text{effluent}) \div \text{average monthly influent}.$$

**C. Surface Water Monitoring**

EPA received comments during the 2007 public comment period regarding the surface water monitoring requirements. Commenters stated that the 2007 draft permit proposed to require surface water monitoring at locations that are outside the influence or control of the dischargers performing the sampling, and that sampling should instead be required exclusively upstream and downstream of each discharger's outfall.

EPA agrees that surface water monitoring upstream and downstream of each discharger's outfall would adequately characterize the dischargers' effect on water quality in the Spokane River. EPA therefore proposes to change the surface water monitoring requirements such that the permit requires surface water monitoring upstream and downstream of each discharger's outfall.

Commenters also stated that the permit should not require surface water monitoring in Skalan Creek. Commenters stated that access to the mouth of the creek (the proposed required sampling point in the 2007 draft permit) required access to private property that could not be assured, and that the creek does not flow for much of the year. Given the lack of reliable access to the mouth of Skalan Creek, the fact that the creek does not flow for much of the year, and the fact that the Spokane River discharges have no influence upon water quality in Skalan Creek, EPA has deleted the surface water monitoring requirements for Skalan Creek from the draft permit. EPA is specifically requesting public comment on the revised surface water monitoring requirements in the draft permit.

<b>Table 5: Surface Water Monitoring Requirements</b>				
<b>Parameter (units)</b>	<b>Sample Locations</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Maximum ML</b>
CBOD <sub>5</sub>	Upstream and Downstream	8/year <sup>1</sup>	Grab	---
Total Ammonia as N (mg/L)	Upstream and Downstream	8/year <sup>1</sup>	Grab	0.05 mg/L
pH (standard units)	Upstream and Downstream	8/year <sup>1</sup>	Grab	---
Total Nitrogen (mg/L)	Upstream and Downstream	8/year <sup>1</sup>	Grab	0.05 mg/L
Total Phosphorus as P (µg/L)	Upstream and Downstream	8/year <sup>1</sup>	Grab	5 µg/L
Orthophosphate as P (µg/L)	Upstream and Downstream	8/year <sup>1</sup>	Grab	5 µg/L
Dissolved Oxygen (mg/L)	Upstream and Downstream	8/year <sup>1</sup>	Grab	---
Chlorophyll a	Upstream and Downstream	8/year <sup>1</sup>	Grab	---
Total Polychlorinated Biphenyls	Upstream and Downstream	quarterly	Grab	10 pg/L (MDL)
Notes: 1. The permittee must sample the receiving water at least twice per month during the months of July, August, September, and October. 2. The permittee must sample the receiving water at least once during the season of April 1 – June 30 and at least once during the season of July 1 – September 30.				

## VI. Sludge (Biosolids) Requirements

EPA Region 10 separates wastewater and sludge permitting. Under the CWA, EPA has the authority to issue separate sludge-only permits for the purposes of regulating biosolids. EPA may issue a sludge-only permit to each facility at a later date, as appropriate.

Until future issuance of a sludge-only permit, sludge management and disposal activities at each facility continue to be subject to the national sewage sludge standards at 40 CFR Part 503 and any requirements of the State's biosolids program. The Part 503 regulations are self-implementing, which means that facilities must comply with them whether or not a permit has been issued.

The absence of specific biosolids requirements in the draft permit is unchanged from the 2007 draft permit. This information is included here for the purpose of providing background context and is not one of the substantial new questions that caused EPA to reopen the public comment period. Therefore EPA is not requesting comments on the absence of specific biosolids requirements in the draft permit at this time.

## **VII. Other Permit Conditions**

### **A. Quality Assurance Plan**

The quality assurance plan requirements (see the revised draft permit at Part II.C) are identical to those in the 2007 draft permit and are explained in the fact sheet dated February 16, 2007. The quality assurance plan requirements are not among the substantial new questions that caused EPA to reopen the public comment period. The requirements are discussed here for the purpose of providing background context. Therefore EPA is not requesting comments on the quality assurance plan requirements at this time.

### **B. Phosphorus Management Plan**

In general, the phosphorus management plan requirements (see the revised draft permit at Part II.B) are similar to those in the 2007 draft permit. However, unlike the 2007 draft permit, the revised draft permit requires that the phosphorus management plan and implementation plan be submitted to EPA and IDEQ, and requires annual reporting of reductions achieved through the phosphorus management plan. The phosphorus management plan requirements are effective year-round, including November – January when no numeric phosphorus limits are in place. EPA is specifically requesting public comments on the phosphorus management plan requirements.

### **C. Pretreatment**

The proposed permit contains requirements that the Board control industrial dischargers, as required by 40 CFR 403 (see the revised draft permit at Part II.E). Indirect dischargers to the treatment plant must comply with the applicable requirements of 40 CFR 403 and any categorical pretreatment standards promulgated by EPA. The pretreatment requirements are not among the substantial new questions that caused EPA to reopen the public comment period and are discussed here for the purpose of providing background context. Therefore, EPA is not requesting comments on the pretreatment requirements at this time.

### **D. Sanitary Sewer Overflows and Proper Operation and Maintenance of the Collection System**

Untreated or partially treated discharges from separate sanitary sewer systems are referred to as sanitary sewer overflows (SSOs). SSOs may present serious risks of human exposure when released to certain areas, such as streets, private property, basements, and receiving waters used for drinking water, fishing and shellfishing, or contact recreation. Untreated sewage contains pathogens and other pollutants, which are toxic. SSOs are not authorized under this permit. Pursuant to the NPDES regulations, discharges from separate sanitary sewer systems authorized by NPDES permits must meet effluent limitations that are based upon secondary treatment. Further, discharges must meet any more stringent effluent limitations that are established to meet State or Tribal water quality standards.

The permit contains language to address SSO reporting and public notice and operation and maintenance of the collection system. The permit requires that the permittee identify SSO occurrences and their causes. In addition, the permit establishes reporting, record keeping and

third party notification of SSOs. Finally, the permit requires proper operation and maintenance of the collection system. The following specific permit conditions apply:

**Immediate Reporting** – The permittee is required to notify the EPA of an SSO within 24 hours of the time the permittee becomes aware of the overflow. (See 40 CFR 122.41(l)(6)).

**Written Reports** – The permittee is required to provide the EPA a written report within five days of the time it became aware of any overflow that is subject to the immediate reporting provision. (See 40 CFR 122.41(l)(6)(i)).

**Third Party Notice** – The permit requires that the permittee establish a process to notify specified third parties of SSOs that may endanger health due to a likelihood of human exposure; or unanticipated bypass and upset that exceeds any effluent limitation in the permit or that may endanger health due to a likelihood of human exposure. The permittee is required to develop, in consultation with appropriate authorities at the local, county, tribal and/or state level, a plan that describes how, under various overflow (and unanticipated bypass and upset) scenarios, the public, as well as other entities, would be notified of overflows that may endanger health. The plan should identify all overflows that would be reported and to whom, and the specific information that would be reported. The plan should include a description of lines of communication and the identities of responsible officials. (See 40 CFR 122.41(l)(6)).

**Record Keeping** – The permittee is required to keep records of SSOs. The permittee must retain the reports submitted to the EPA and other appropriate reports that could include work orders associated with investigation of system problems related to a SSO, that describes the steps taken or planned to reduce, eliminate, and prevent reoccurrence of the SSO. (See 40 CFR 122.41(j)).

**Proper Operation and Maintenance** – The permit requires proper operation and maintenance of the collection system. (See 40 CFR 122.41(d) and (e)). SSOs may be indicative of improper operation and maintenance of the collection system. The permittee may consider the development and implementation of a capacity, management, operation and maintenance (CMOM) program.

The permittee may refer to the Guide for Evaluating Capacity, Management, Operation, and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems (EPA 305-B-05-002). This guide identifies some of the criteria used by EPA inspectors to evaluate a collection system's management, operation and maintenance program activities. Owners/operators can review their own systems against the checklist (Chapter 3) to reduce the occurrence of sewer overflows and improve or maintain compliance.

## **E. Additional Permit Provisions**

Sections III, IV, and V of the draft permit contain standard regulatory language that must be included in all NPDES permits. Because they are regulations, they cannot be challenged in the context of an NPDES permit action. The standard regulatory language covers requirements such as monitoring, recording, and reporting requirements, compliance responsibilities, and other general requirements.

## VIII. Other Legal Requirements

### A. Endangered Species Act and Essential Fish Habitat

As explained in the fact sheet dated February 16, 2007, EPA has determined that the discharge will have no effect on any threatened or endangered species. In general, the effluent limitations in the revised draft permit are as stringent as or more stringent than those in the 2007 draft permit. Furthermore, on August 9, 2007, the bald eagle was removed from the list of threatened and endangered species. Therefore, consultation under the Endangered Species Act is not necessary.

### B. State/Tribal Certification

Section 401 of the CWA requires EPA to seek State or Tribal certification before issuing a final permit. As a result of the certification, the State may require more stringent permit conditions or additional monitoring requirements to ensure that the permit complies with water quality standards.

### C. Permit Expiration

The permit will expire five years from the effective date.

## IX. References

Butkus, Steve and K. Merrill. 1999. *Spokane River Dissolved Metals Total Maximum Daily Load*. Water Quality Program. Washington State Department of Ecology. Olympia, WA. Publication #99-49-WQ. May 1999.

Coots, Randy and C. Deligeannis. 2010. *PCBs, Dioxins, and Furans in Fish, Sediment, and Wastewater Treatment Plant Effluent from West Medical Lake*. Toxics Studies Unit. Environmental Assessment Program. Washington State Department of Ecology. Olympia, WA. Publication # 10-03-038. September 2010.

EPA. 1991. *Technical Support Document for Water Quality-based Toxics Control*. US Environmental Protection Agency. Office of Water. EPA/505/2-90-001. March 1991.

EPA. 1994. *Method 1613: Tetra- through Octa-Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS*. US Environmental Protection Agency. Office of Water. Engineering and Analysis Division. October 1994.

EPA. 1996a. *Interim Guidance for Performance - Based Reductions of NPDES Permit Monitoring Frequencies*.

EPA. 1996b. *Regions 9 and 10 Guidance for Implementing Whole Effluent Toxicity Testing Programs*.

EPA. 2002. *National Recommended Water Quality Criteria: 2002 Human Health Criteria Calculation Matrix*. US Environmental Protection Agency. Office of Water. EPA-822-R-02-012. November 2002.

EPA. 2005. *Guide for Evaluating Capacity, Management, Operation, and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems*. US Environmental Protection Agency, Office of Enforcement and Compliance Assurance, EPA 305-B-05-002.

EPA. 2007. *Biological Evaluation for Reissuance of NPDES Permits to the Cities of Coeur d'Alene and Post Falls and the Hayden Area Regional Sewer Board*. EPA Region 10. Office of Water and Watersheds.

Johnson, Art, B. Era-Miller, R. Coots, and S. Golding. 2004. *A Total Maximum Daily Load Evaluation for Chlorinated Pesticides and PCBs in the Walla Walla River*. Washington State Department of Ecology. Environmental Assessment Program. Olympia, WA. Publication # 04-03-032. October 2004.

Moore, David J. and J. Ross. 2010. *Spokane River and Lake Spokane Dissolved Oxygen Total Maximum Daily Load Water Quality Improvement Report*. Washington State Department of Ecology. Eastern Regional Office. Spokane, WA. Publication # 07-10-073. Revised February 2010.

Serdar, Dave. 2003. *TMDL Technical Assessment of DDT and PCBs in the Lower Okanogan River Basin*. Washington State Department of Ecology. Environmental Assessment Program. Olympia, WA. Publication #03-03-013. July 2003.

Serdar, Dave, B. Lubliner, A. Johnson, and D. Norton. 2011. *Spokane River PCB Source Assessment 2003-2007*. Toxics Studies Unit. Environmental Assessment Program. Washington State Department of Ecology. Olympia, WA. Publication # 11-03-013. April 2011.

USGS. 2003. *Ecological Indicators of Water Quality in the Spokane River, Idaho and Washington, 1998 and 1999*. United States Department of the Interior. U.S. Geological Survey. FS-067-03. September 2003.



## Appendix A: Facility Map



DRAFT — January 2012



## **Appendix B: Water Quality-based Effluent Limits for Phosphorus, Ammonia and Carbonaceous Biochemical Oxygen Demand Necessary to Meet Water Quality Criteria for Dissolved Oxygen in Washington and Nutrients in Idaho**

### **A. Overview**

Federal regulations require NPDES permits to be conditioned to ensure compliance with the water quality requirements of all affected States (40 CFR 122.4(d), 122.44(d)(4), see also Clean Water Act Section 401(a)(2)). EPA has determined that waters of the State of Washington are affected by discharges of nutrient and oxygen-demanding pollution, specifically total phosphorus (TP), five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), and total ammonia as nitrogen (ammonia), from point sources in Idaho. These three pollutants can decrease dissolved oxygen concentrations in the Spokane River and in Lake Spokane, in the State of Washington. Thus, EPA must establish water quality-based effluent limits for these parameters, which ensure that the level of water quality to be achieved by limits on point sources is derived from and complies with all applicable water quality standards, including Washington water quality standards (40 CFR 122.44(d)(1)(vii)(A)). Some of the applicable water quality standards for the State of Washington explicitly require that the cumulative impact of all human actions be considered. Therefore, the effluent limits will assure that these discharges, considered cumulatively with all other human sources of pollution, including those in the State of Washington, will achieve the Washington DO standard in Lake Spokane.

### **B. Requirement to Meet Washington's Water Quality Standards**

The federal regulation 40 CFR 122.4(d) states that “no permit may be issued...when the imposition of conditions cannot ensure compliance with the applicable water quality requirements of all affected States.” In the reasonable potential analysis described below, EPA determined that discharges of TP, CBOD<sub>5</sub>, and ammonia from the City of Coeur d'Alene, the City of Post Falls and the Hayden Area Regional Sewer Board affect water quality in waters of the State of Washington, because they have the reasonable potential to cause or contribute to excursions below Washington's water quality criteria for DO. Therefore, the State of Washington is an “affected State” under 40 CFR 122.4(d).

Furthermore, 40 CFR 122.44(d)(4) requires that NPDES permits must include any requirements necessary to “conform to applicable water quality requirements under section 401(a)(2) of CWA when the discharge affects a State other than the certifying State.” Therefore, EPA must establish conditions in the permits for these facilities, which ensure compliance with the applicable water quality requirements of the State of Washington.

### ***Reasonable Potential Analysis***

The federal regulation 40 CFR 122.44(d)(1)(i), which implements Section 301(b)(1)(C) of the Clean Water Act, requires that NPDES permits contain water quality-based effluent limitations for all pollutants or pollutant parameters that EPA determines are or may be discharged at a level that will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including narrative criteria for water quality.

In the fact sheets for the 2007 draft permits for the Cities of Coeur d'Alene and Post Falls and the Hayden Area Regional Sewer Board, EPA found that the discharges of oxygen-demanding pollution from those sources have the reasonable potential to cause or contribute to excursions below Washington's water quality criterion for dissolved oxygen in Lake Spokane. Specifically, the modeling conducted in support of the 2007 draft Idaho permits showed that the levels of discharge allowed by the 1999 permits, from the Idaho wastewater treatment plants alone, could decrease dissolved oxygen concentrations in Lake Spokane by 0.57 mg/L as an average over depth below 8 meters, at the time and location of maximum impact.<sup>1</sup> Washington's water quality standard only allows a DO decrease of 0.2 mg/L below the natural condition for all human sources considered cumulatively (see "Applicable Water Quality Standards and Status of Waters," below). Therefore, a decrease of 0.57 mg/L would cause an excursion above Washington's water quality criterion for DO in lakes and reservoirs (because it is a greater decrease than allowed by the standards). In addition, the modeling conducted in support of the 2007 draft Idaho permits showed that currently permitted levels of discharge could increase pH at the state line to more than 9.0 standard units, which is an excursion above both Idaho and Washington water quality standards (Cope 2006).

Reasonable potential determinations must account for existing controls on point and nonpoint sources of pollution (40 CFR 122.44(d)(1)(ii)). Additional anthropogenic nutrients and oxygen demand discharged by municipal separate storm sewer systems in Idaho further contribute to excursions below dissolved oxygen standards, which serves as additional evidence for the reasonable potential finding.

Therefore, the discharges of TP, ammonia, and CBOD<sub>5</sub> from the three WWTPs discharging to the Spokane River in Idaho affect water quality in waters of the State of Washington and have the reasonable potential to cause or contribute to excursions above water quality standards for dissolved oxygen and pH in waters of the State of Washington. EPA has therefore established water quality-based effluent limits for TP, ammonia and CBOD<sub>5</sub> for the Idaho dischargers to the Spokane River that ensure a level of water quality that is derived from and complies with both Washington's and Idaho's water quality standards (40 CFR 122.44(d)(1)(vii)(A)).

### **C. Applicable Water Quality Standards and Status of Waters**

Lake Spokane (also called "Long Lake"), a reservoir located in the State of Washington, and the segments of the Spokane River between the Idaho-Washington border and Lake Spokane, are listed as impaired for DO in Washington's 2008 303(d)/305(b) integrated report. The Spokane River is also listed as a "water of concern" (category 2) for pH in Washington.

The Spokane River is not impaired for dissolved oxygen or pH in the State of Idaho. However, the entire length of the Spokane River that is in Idaho (i.e., both above and below the Post Falls Dam) is listed in Idaho's 2010 303(d)/305(b) integrated report as being impaired for TP. See

---

<sup>1</sup> The fact sheets for the 2007 draft permits for the City of Coeur d'Alene, the City of Post Falls, and the Hayden Area Regional Sewer Board stated the maximum DO decrease in Lake Spokane resulting from currently permitted Idaho discharges as 1.1 mg/L. This was the 95<sup>th</sup> percentile DO decrease, over the depth of the lake, at the time and location of maximum impact, predicted under the "Permit" modeling scenario (Cope 2006). The Spokane DO TMDL quantifies the DO decrease as the average DO decrease, over the depth of the lake, below 8 meters (see the Spokane DO TMDL at page 36). When this metric is applied to the "Permit" scenario described in the 2006 Cope report and the 2007 fact sheets, the Idaho wastewater treatment plants' potential impact on DO, based on currently-permitted levels of discharge, is 0.57 mg/L.

Table 1, below, for a summary of the applicable water quality criteria for DO, pH, and nutrients or aesthetics for the Spokane River and Lake Spokane in the States of Idaho and Washington.

<b>Table 1: Dissolved Oxygen and pH Criteria for the Spokane River and Lake Spokane</b>		
<b>Spokane River</b>		
<b>Parameter</b>	<b>Idaho Standards</b>	<b>Washington Standards</b>
<b>Dissolved Oxygen</b>	<p><b>Numeric Criteria:</b>  <u>Below Post Falls Dam, except during August and September:</u> One (1) day minimum of not less than six point zero (6.0) mg/l or ninety percent (90%) of saturation, whichever is greater.  <u>Other times and locations:</u> Dissolved Oxygen Concentrations exceeding six (6) mg/l at all times.            (IDAPA 58.01.02, Sections 110.12 and 250)  <b>Natural condition provision:</b> When natural background conditions exceed any applicable water quality criteria set forth in Sections 210, 250, 251, 252, or 253, the applicable water quality criteria shall not apply; instead, there shall be no lowering of water quality from natural background conditions.            (IDAPA 58.01.02.200.09.)</p>	<p><b>Numeric Criteria:</b>  <u>From Nine Mile Bridge (river mile 58.0) to the Idaho border (river mile 96.5):</u> 1-day minimum of 8.0 mg/L.  <u>From Long Lake Dam (river mile 33.9) to Nine Mile Bridge:</u> 1-day minimum of 9.5 mg/L.            (WAC 173-201A, Tables 200(1)(d) and 602)  <b>Natural condition provision:</b> When a waterbody's D.O. is lower than the criteria in Table 200 (1)(d) (or within 0.2 mg/L of the criteria) and that condition is due to natural conditions, then human actions considered cumulatively may not cause the D.O. of that water body to decrease more than 0.2 mg/L.            (WAC 173-201A-200(1)(d)(i))</p>
<b>pH</b>	<p>Within the range of six point five (6.5) to nine point zero (9.0).            (IDAPA 58.01.02.250.01.a).</p>	<p><u>From Nine Mile Bridge (river mile 58.0) to the Idaho border (river mile 96.5):</u> pH shall be within the range of 6.5 to 8.5 with a human-caused variation within the above range of less than 0.5 units.  <u>From Long Lake Dam (river mile 33.9) to Nine Mile Bridge:</u> pH shall be within the range of 6.5 to 8.5, with a human-caused variation within the above range of less than 0.2 units.            (WAC 173-201A, Tables 200(1)(g) and 602)</p>
<b>Natural Conditions Definition</b>	<p>The physical, chemical, biological, or radiological conditions existing in a water body without human sources of pollution within the watershed. Natural disturbances including, but not limited to, wildfire, geologic disturbance, diseased vegetation, or flow extremes that affect the physical, chemical, and biological integrity of the water are part of natural background conditions. Natural background conditions should be described and evaluated taking into account this inherent variability with time and place.            (IDAPA 58.01.02.010.56)</p>	<p>“Natural conditions” or “natural background levels” means surface water quality that was present before any human-caused pollution. When estimating natural conditions in the headwaters of a disturbed watershed it may be necessary to use the less disturbed conditions of a neighboring or similar watershed as a reference condition.            (WAC 173-201A-020)</p>
<b>Nutrients / Aesthetics</b>	<p>Surface waters of the state shall be free from excess nutrients that can cause visible slime growths or other nuisance aquatic growths impairing designated beneficial uses.            (IDAPA 58.01.02.200.06)</p>	<p>Aesthetic values must not be impaired by the presence of materials or their effects, excluding those of natural origin, which offend the senses of sight, smell, touch, or taste (see WAC 173-201A-230 for guidance on establishing lake nutrient standards to protect aesthetics).            (WAC 173-201A-260(2)(b))</p>
<b>Lake Spokane (Washington Water Quality Standards)</b>		
<b>Dissolved Oxygen</b>	<p>For lakes, human actions considered cumulatively may not decrease the dissolved oxygen concentration more than 0.2 mg/L below natural conditions. (WAC 173-201A-200(1)(d)(ii))</p>	

***Requirement for Cumulative Analysis of Human Actions***

Washington's water quality criterion for dissolved oxygen in lakes and reservoirs requires that "human actions considered cumulatively may not decrease the dissolved oxygen concentration more than 0.2 mg/L below natural conditions" (emphasis added). In order to assure that the Idaho sources meet Washington State standards, the dissolved oxygen impact of discharges from Idaho sources must be considered cumulatively with the impact of the Washington sources.

**D. Modeling Supporting the Permit Limits**

The Clean Water Act's primary mechanism for addressing water quality impairments on a cumulative basis is the total maximum daily load (TMDL) process. However, TMDLs are generally prepared by the States, and a TMDL prepared by a State cannot establish load and wasteload allocations for pollution sources located outside the boundaries of that State. However, when a State prepares a TMDL, the State may reasonably assume that NPDES permits for point sources in upstream States, which have an effect on water quality in the downstream State that is preparing the TMDL, will include effluent limits that ensure compliance with the downstream State's water quality requirements, including water quality standards, because this is required by federal regulations (40 CFR 122.4(d), 40 CFR 122.44(d)(4)). Furthermore, if EPA is the NPDES permitting authority for the point source discharges in the upstream State (as it is in this case) the downstream State may object to the issuance of the permits in the upstream state, if the federal permits in the upstream State will affect the quality of its waters so as to violate any water quality requirements in the downstream State (CWA Section 401(a)(2)). When the Washington State Department of Ecology (Ecology) prepared the *Spokane River and Lake Spokane Dissolved Oxygen Total Maximum Daily Load* (TMDL) Ecology assumed that the NPDES permits for point sources discharging to the Spokane River in Idaho would include limits that would ensure compliance with Washington's water quality standards.

***The DO TMDL's Modeling Assumptions for Idaho Point Sources***

To ensure that the TMDL's load and wasteload allocations, Avista's DO responsibility, and the loadings from Idaho would cumulatively meet DO WQS in Lake Spokane, when developing the TMDL, Ecology modeled the cumulative impact of both Idaho and Washington pollution sources upon the lake.

The TMDL states: "The dissolved oxygen depletion predicted to result from these assumed Idaho pollutant loads is shown in Tables 14 and 15 of PSU (2010) (the Idaho only source assessment scenario results). EPA will incorporate permit limits into the NPDES permits for Idaho point source dischargers that ensure that the total dissolved oxygen depletion resulting from those dischargers is no greater than that shown in Tables 14 and 15 of (the Spokane River Modeling Final Scenarios Report 2010, the "2010 modeling report," by Portland State University)." Id. at 35.

Thus, when developing the TMDL, Ecology assumed certain loadings of oxygen-demanding pollution would be discharged in Idaho (shown in the 2010 modeling report at Table 2, the "prior modeling assumptions"), and the modeling supporting the TMDL thereby accounts for any dissolved oxygen decrease resulting from sources in Idaho. However, the TMDL does not apply to the Idaho permits, and the prior modeling assumptions are not binding on EPA when it drafts the Idaho permits. The prior modeling assumptions are not wasteload allocations with which the

effluent limits in the Idaho permits must be consistent (40 CFR 122.44(d)(1)(vii)(B)). EPA is free to establish any limits in the Idaho permits for CBOD<sub>5</sub>, ammonia and TP so long as those limits ensure compliance with both Idaho and Washington WQS, when considered cumulatively with other sources of pollution (40 CFR 122.4(d), 122.44(d)(4)).

The language on Page 35 of the TMDL assumed that, in order to determine if the effluent limits in the Idaho permits would meet Washington's DO criteria, EPA would isolate the impact of the Idaho point sources and then evaluate those results against the DO impact of the Idaho sources as assumed in the TMDL modeling. The limits would then be set to ensure that the DO depletion from Idaho sources, specifically, was no greater than assumed in the TMDL. This approach would ensure compliance with Washington water quality standards for DO on a cumulative basis by ensuring that the DO impact from *both* Idaho and Washington sources (and therefore the cumulative DO impact from sources in both States) was the same or less than predicted by the TMDL modeling.

However, EPA believes it is more realistic to conduct the modeling supporting effluent limits for Idaho point sources to reflect the cumulative effect of all human actions that influence DO and to then evaluate the modeling results against Washington's water quality standards. This approach more directly ensures compliance with Washington's water quality standards on a cumulative basis. Thus, the effluent limits are based on modeling of all known human sources of nutrient and oxygen-demanding pollution (i.e. point and non-point sources in Washington and Idaho).

### ***Summary of Model Results***

The effluent limits in the draft permits are not the same as the loadings that were assumed in the TMDL, for Idaho point sources. However, as explained below, the effluent limits for Idaho point sources ensure compliance with Washington's water quality standards for dissolved oxygen, when considered cumulatively with the Washington NPDES permits' effluent limits, the TMDL's load allocations for oxygen-demanding pollution from non-point sources, and Avista's dissolved oxygen responsibility (LimnoTech 2011, PSU 2011).

The effluent limits meet Washington's DO criteria (WAC 173-201A-200(1)(d)) when the precision of the water quality model is considered (as explained in detail below). The effluent limits in the Washington and Idaho NPDES permits do not decrease the cumulative average dissolved oxygen in the shaded cells in Table 7 of the final TMDL (i.e., when and where Avista has a DO responsibility) relative to the prior modeling assumptions. In fact, the effluent limits *improve* the dissolved oxygen by 0.006 mg/l relative to the prior modeling assumptions and Washington wasteload allocations when averaged over all reservoir segments and all times of Avista responsibility.

### **Model Precision**

With three exceptions, each individual model output result ensures compliance with Washington's DO criteria (WAC 173-201A-200(1)(d)), when considered cumulatively with the load allocations in Table 6 of the TMDL and Avista's DO responsibility as reported in Table 7 of the TMDL, after results are rounded to the nearest 0.1 mg/l. Each of the three exceptions is characterized by a markedly low arithmetic tolerance for any decrease in DO relative to the TMDL modeling. That is to say, in each of these instances, the DO sag resulting from point and non-point controls under the TMDL scenario, after considering Avista's responsibility, was just slightly less than 0.25 mg/L. Thus, in those instances, a very small additional DO sag (e.g., 0.002

mg/L) would cause the difference, rounded to the nearest 0.1 mg/L, to change from 0.2 mg/L to 0.3 mg/L. The actual DO decreases in the three exceptions, relative to the TMDL, were 0.002 – 0.003 mg/L (see Table 2, below).

<b>Table 2: Increases in Rounded DO Sag to 0.3 mg/L</b>			
<b>Segment</b>	<b>Time Period</b>	<b>Tolerance (mg/L)</b>	<b>Modeled DO Change Relative to TMDL (mg/L)</b>
188	July 1-15	0.0008	-0.003
188	September 1-15	0.0001	-0.002
186	September 16-30	0.0014	-0.003

EPA believes these deviations are within the precision of the CE-QUAL-W2 model. In a memo dated December 28, 2010, LimnoTech described some issues encountered when performing a sensitivity analysis for the Idaho point sources. As stated on Page 2 of the memo, a reduction in Post Falls' CBOD<sub>5</sub> discharge (with all other model inputs held constant) actually effected a 0.002 mg/L *decrease* in the average DO in the reservoir, in times and locations where Avista has a DO responsibility. Other inputs being equal, the DO should have *increased* in response to decreased CBOD discharges. Even if the change in CBOD<sub>5</sub> loading was too small to have any discernible impact, the DO should have, at a minimum, been unchanged. Thus, it is reasonable to consider the difference between these two results (0.002 mg/L) to be within the precision of the model for the average DO in times and locations where Avista has a DO responsibility.

Because this average DO is computed from 106 individual results, the model is less precise than 0.002 mg/L for any individual result. Therefore, EPA believes that the 0.002 – 0.003 mg/L deviations from the TMDL scenario, which resulted in a 0.3 mg/L rounded DO sag in three instances, are within the precision of the CE-QUAL-W2 model. Two results that vary by less than the precision of the model are functionally the same result.

#### Improvements in DO Relative to the TMDL

Under the proposed effluent limits for Idaho and Washington point sources, the cumulative DO sag, rounded to the nearest tenth of a milligram per liter, would actually decrease to 0.1 mg/L from 0.2 mg/L in five instances, as shown in Table 3, below. Also, as stated above, the alternative improves the dissolved oxygen by 0.006 mg/l (relative to the TMDL) when averaged over all segments and times of Avista responsibility. This means that any decreases in DO concentrations relative to the TDML scenario, at specific times and locations, are balanced by DO improvements at other times and in other locations.

<b>Table 3: Decreases in Rounded DO Sag to 0.1 mg/L</b>		
<b>Segment</b>	<b>Time Period</b>	<b>Modeled Change Relative to TMDL (mg/L)</b>
172	August 1-15	+0.007
177	September 1-15	+0.018
185	September 1-15	+0.001
175	September 16-30	+0.025
180	September 16-30	+0.018

#### The Exceptions are Very Infrequent

The three instances where the cumulative DO sag increased to 0.3 mg/L, when rounded to the tenths place, comprise less than 3% of the times and locations where Avista has a DO responsibility (106 total), and 0.7% of all of the times and locations that were evaluated in Table

7 of the TMDL (448 total). Since Table 7 of the Spokane River DO TMDL only provides DO results for June 1st - December 31st, and modeling indicates no violations of DO WQS prior to June 1st, this percentage would be even smaller than 0.7% on a year-round basis.

#### The TMDL's Margin of Safety

The TMDL has an implicit margin of safety comprised of several conservative assumptions (see the TMDL at Page 51). Some of these will tend to exaggerate the impact of nutrients and oxygen demand discharged by point sources. Specifically:

- Low flows (year 2001) were used as the baseline hydrologic condition.
- All TP is assumed to be bioavailable.<sup>2</sup>
- The top eight meters of the reservoir are not included in the vertical averaging because of amplified algal activity which increases daytime dissolved oxygen levels.

Therefore, the actual DO impact of the point source discharges may be somewhat less than that predicted by the model.

#### Conclusion

Because the effluent limits in the Idaho and Washington NPDES permits are equivalent to the scenario used to develop the Spokane River TMDL for the reasons described above, EPA believes that these effluent limits will ensure compliance with Washington's water quality standards for DO, when considered cumulatively with other actions taking place under the TMDL.

#### ***Effluent Flow Rates used in the Model Inputs***

In 2009, EPA asked the City of Coeur d'Alene, the City of Post Falls, and the Hayden Area Regional Sewer Board to provide effluent flow rate projections for the year 2027, for use in developing the Spokane River TMDL and those facilities' NPDES permits. The flow projections provided by the utilities at that time were between 6.4 and 7.9 mgd for the City of Coeur d'Alene, 5.0 mgd for the City of Post Falls, and 3.2 mgd for the Hayden Area Regional Sewer Board. After further discussion with the City of Coeur d'Alene and IDEQ, a flow projection of 7.6 mgd was established for the City of Coeur d'Alene.

These flows are similar to projections made in 2005 (for the year 2028) as part of the Spokane River TMDL collaboration process. The 2005 flow projections were 7.0 mgd for the City of Coeur d'Alene, 5.7 mgd for the City of Post Falls, and 3.2 mgd for HARSB (Spokane River DO TMDL Collaboration Flows and Loadings Workgroup 2005). For Idaho point sources, the modeling supporting the TMDL was based on the effluent flow rates projected in 2009 and effluent concentrations described in the 2010 modeling report at Table 2 (PSU 2010). For the City of Coeur d'Alene and HARSB, these flow projections were also used to determine calculate the effluent limits in the draft permits, as described below.

In March 2010, JUB Engineers completed a revised flow projection for the City of Post Falls, which was 7.65 mgd (JUB 2010). The projection considered projected population growth within the service area, and a 25% addition for wastewater from non-municipal uses. For the City of

---

<sup>2</sup> The model partitions point source phosphorus into two fractions: One which is immediately bioavailable and another that is not immediately bioavailable but becomes bioavailable over time according to first-order kinetics.

Post Falls, the increased pollutant loads resulting from this increased flow rate (relative to the 2005 and 2009 projections) were represented in the model using proportionally increased effluent concentrations, instead of an increased effluent flow (see Table 4 below).

### ***Basis for Loads***

The model input effluent concentrations of TP, CBOD<sub>5</sub>, and ammonia for each of the Idaho point sources are summarized in Table 4, below. The seasonal average loads of TP, ammonia, and CBOD<sub>5</sub> that are necessary to meet Washington's water quality criterion for DO in Lake Spokane, based on the modeling supporting the TMDL, are calculated by multiplying the projected flow rates for each facility, which were used in the modeling, by the modeled concentrations and the density of water (8.34 lb/gallon). The resulting seasonal average loads are shown in Table 4, below.

<b>Table 4: Idaho Loads used in Modeling Supporting the Permit Limits</b>							
Point Source Discharge	Modeled Flow Rate (mgd)	Seasonal Average Modeled Concentrations, February – October Unless Otherwise Noted (mg/L)			Seasonal Average Modeled Loads, February – October Unless Otherwise Noted (lb/day)		
		Ammonia	TP	CBOD <sub>5</sub>	Ammonia	TP	CBOD <sub>5</sub>
City of Coeur d'Alene WWTP	7.6	4.29 (Mar. – Oct.)	0.05	3.56 (Feb. – Mar.)	<b>272</b> (Mar. – Oct.)	<b>3.17</b>	<b>226</b> (Feb. – Mar.)
				3.2 (Apr. – Oct.)			<b>203</b> (Apr. – Oct.)
HARSB WWTP	3.2	2.9	0.05	2.9	<b>77.4</b>	<b>1.33</b>	<b>77.4</b>
City of Post Falls WWTP <sup>1</sup>	5.0	6.1	0.0765	6.1	<b>255</b>	<b>3.19</b>	<b>255</b>
<b>Notes:</b> 1. Effluent loads for the City of Post Falls are equivalent to a discharge of 0.05 mg/L TP, 4.0 mg/L CBOD <sub>5</sub> , and 4.0 mg/L ammonia at a flow rate of 7.65 mgd.							

### **E. Translating the Modeled Loads to Effluent Limits**

The modeled loads in Table 4 are seasonal average values. However, 40 CFR 122.45(d)(2) states that “(f)or continuous discharges all permit effluent limitations, standards, and prohibitions, including those necessary to achieve water quality standards, shall unless impracticable be stated as...(a)verage weekly and average monthly discharge limitations for POTWs.”

In some cases, it is impracticable to express effluent limits as average monthly limits and average weekly limits. In the draft permits for the City of Coeur d'Alene, City of Post Falls, and Hayden Area Regional Sewer Board, the effluent limits for E. coli, chlorine, metals, TP, and, in some cases, ammonia and CBOD are not expressed as average monthly limits and average weekly limits. The basis for expressing effluent limits for E. coli, chlorine, ammonia and metals using averaging periods other than monthly and weekly is explained in Appendices C and E. The basis for expressing HARSB's CBOD limits as seasonal averages, under some circumstances, is explained in Appendix C to the HARSB fact sheet.

In addition, EPA has determined that it is impracticable to express effluent limits for TP as monthly average and weekly average limits, in this case, for the reasons discussed below. Effluent limits for TP are expressed as seasonal average loading limits that are identical to the loads of TP simulated in the modeling.



***Basis for Expressing Effluent Limits for TP as Seasonal Average Limits***

In a memorandum dated March 3, 2004 (the Chesapeake Bay Memo), James A. Hanlon, the director of EPA's Office of Wastewater Management, stated that, for the protection of Chesapeake Bay and its tidal tributaries from excess nutrient loading, it was impracticable to express permit effluent limitations for nutrients (total nitrogen and TP) as daily maximum, weekly average, or monthly average effluent limitations.

The Chesapeake Bay Memo states that:

*“Establishing appropriate permit limits (for nitrogen and TP) for Chesapeake Bay and its tidal tributaries is different from setting limits for other parameters such as toxic pollutants because: the exposure period of concern for nutrients loading to Chesapeake Bay and its tidal tributaries is very long; the area of concern is far-field (as opposed to the immediate vicinity of the discharge); and the average pollutant load rather than the maximum pollutant load is of concern”* (Page 2).

The Chesapeake Bay Memo further states that:

*“The nutrient dynamics of (Chesapeake) Bay may not be unique. The establishment of an annual limit with a similar finding of ‘impracticability’ pursuant to 40 CFR 122.45(d) may be appropriate for the implementation of nutrient criteria in other watersheds when: attainment of the criteria is dependent on long-term average loadings rather than short-term maximum loadings; the circumstances match those outlined in this memo for Chesapeake Bay and its tidal tributaries; annual limits are technically supportable with robust data and modeling as they are in the Chesapeake Bay context; and appropriate safeguards to protect all other applicable water quality standards are employed”* (Pages 2-3).

Similar to Chesapeake Bay, EPA believes that a finding of impracticability is appropriate in this case as well under 40 CFR 122.45(d).

**Modeling Supports the use of Seasonal Average Limits**

As stated in the TMDL (Page 33), the wasteload allocations for Washington point sources and the loading assumptions for the Idaho point sources are seasonal average values. Thus, attainment of dissolved oxygen criteria in Lake Spokane is based on long-term average loadings rather than short-term maximum loadings.

Modeling has shown that highly variable discharges from Spokane River point sources, which have an average of 50 µg/L TP, have a very similar impact upon DO in Lake Spokane relative to constant discharges from those sources of exactly 50 µg/L each day (HDR 2009). At times and in locations where Avista had a dissolved oxygen responsibility in the TMDL (see TMDL at Table 7, Pages 49-50), on average, the variable discharge scenario resulted in a 0.003 mg/L *improvement* in DO relative to constant discharges. The variable discharges increased DO by as much as 0.09 mg/L relative to constant discharges in some segments, and the maximum decrease in DO in any reservoir segment at any time was only 0.05 mg/L. Therefore, dissolved oxygen in

Lake Spokane is insensitive to short-term increases in TP loading, as long as the seasonal average TP load remains unchanged.

#### The TP Limits are intended to Control Far Field Effects

Similar to Chesapeake Bay, the TP effluent limits are intended to control far-field effects. Lake Spokane is a 24-mile-long reservoir, the upstream end of which is 42.5 miles downstream from the closest Idaho POTW (the City of Post Falls).

#### The Permits Include Additional Requirements to Ensure Water Quality Standards are Met with the use of Seasonal Limits

Finally, the draft permits include additional requirements to ensure that water quality standards are met. These requirements include required reporting of monthly average TP loadings. In addition, if, at the end of any month from February through September, the average TP discharge measured to date is greater than the seasonal average loading limit, the permittee must submit a report explaining how it will lower its TP loadings in order to comply with the seasonal average effluent limitations.

#### The Future Effluent Variability is Unknown

In order to calculate average monthly and average weekly limits that are consistent with a seasonal average load, the effluent variability must be known. Effluent variability may be quantified by the coefficient of variation (CV), which is the ratio of the standard deviation to the mean of the effluent data (also called the relative standard deviation).

Because the TP effluent limits require levels of discharge much lower than current levels, the treatment systems must be upgraded in order to achieve compliance with the TP limits. While historical monitoring data are available, which could be used to quantify the variability of TP in the *existing* treatment facilities, the variability of TP in the effluent, after these upgrades are completed, is unknown.

On Page E-3, the TSD states that “typical values for the CV range from 0.2 to 1.2.” EPA’s *Nutrient Removal Technologies Reference Document* (EPA 832-R-08-006) and a technical memorandum submitted to the Spokane River TMDL collaboration titled “Evaluation of Exemplary WWTPs Practicing High Removal of Phosphorus,” by Dave Reynolds of CH2M HILL and Dave Clark of HDR, Inc (November 21, 2005) provide CVs for other POTWs that remove TP. In general, coefficients of variation are within the “typical” range identified by the TSD, but some facilities exhibit CVs that are higher or lower than the typical range (see Table 5, below). Because the loading levels in the TMDL and modeling are long-term (February – October or March – October) average values, the value of the CV can have a significant impact on the value of the average monthly limit. For example, according to Table 5-2 of the TSD, if a facility that sampled for TP 10 times per month had a CV of 0.2, its 95th percentile probability basis average monthly limit should be set at 1.12 times the long-term average. If that facility’s CV were equal to 1.2, that facility’s average monthly limit should be set at 1.80 times the long-term average. The facility with a CV of 1.2 would have an average monthly limit 60% greater than a facility with a CV of 0.2. If the limits are set at the 99th percentile probability basis, the difference between limits based on a CV of 1.2 as opposed to a CV of 0.2 becomes even larger.

If the CV is not known, an estimate can be made. In fact, it is common practice in the calculation of effluent limits for toxic parameters to assume that the CV is equal to 0.6, if the actual CV is unknown (see the TSD at Pages 53 and E-3). However, in the context of calculating

average monthly and average weekly limits from a fixed long-term average, if the estimated CV is less than the actual CV, the effluent limits will be artificially stringent. Conversely, if the estimated CV is greater than the actual CV, the permittee may be able to consistently discharge at levels greater than those modeled, yet maintain compliance with the average monthly effluent limits. This possibility is recognized in the Chesapeake Bay Memo (see Page 4). The Chesapeake Bay Memo also points out that “the effluent loading of nutrients is not constant due to seasonal temperature fluctuations in northern climates” because biological nutrient removal is less effective at lower temperatures (Page 5). The TSD does not provide a means to account for this additional variability in the effectiveness of biological nutrient removal due to temperature.

<b>Table 5: Coefficients of Variation (CV) for POTWs Removing Phosphorus (Sorted by CV)</b>		
<b>Facility</b>	<b>Average TP (ug/L)</b>	<b>CV</b>
Chelsea, MI	90	0.14
Kalispell, MT	120	0.19
Kelowna, BC	140	0.21
Lee County, FL	102	0.35
Las Vegas	144	0.37
Pinery	30	0.38
Clearwater, FL Marshall St	130	0.40
Cauley Creek	105	0.44
Rock Creek	77	0.48
Lone Tree	32	0.48
Noman Cole	104	0.48
Genessee County, MI	240	0.50
Johnston Co, NC	260	0.62
Hyattsville, MD	430	0.62
McMinnville, OR	58	0.63
North Cary, NC	380	0.64
Durham	102	0.66
Clearwater, FL Northeast	200	0.82
Piscataway, MD	90	0.89
Iowa Hill	9	0.97
Hyrum, UT	70	1.07
Hagerstown, MD	660	1.45

In contrast, as stated on Page E-3 of the TSD, when calculating effluent limits for toxic parameters, “in many cases, changes in the CV will have little impact on the final permit limit.” This is because the averaging periods for water quality criteria for toxic parameters are very short (generally 4 days for chronic aquatic life criteria and 1 hour for acute aquatic life criteria, see IDAPA 58.01.02.010). Effluent limits for toxic parameters must therefore control short-term peak concentrations. This constrains the effluent limit calculations, making the final effluent limits relatively insensitive to effluent variability.

#### Seasonal Average TP Limit Summary

In summary, modeling shows that, similar to Chesapeake Bay, dissolved oxygen concentrations in Lake Spokane are related not to maximum TP loading but to long-term average TP loading. That is to say, Lake Spokane is insensitive to short-term increases in TP loading from Idaho point sources, as long as the seasonal average is not increased. The effluent limits for TP in this case are based on far-field, as opposed to near-field, water quality concerns. Because the future

variability of TP concentrations and loadings in these effluents is unknown, EPA cannot calculate appropriate monthly average and weekly average effluent limits for TP with any degree of certainty. If EPA were to assume a CV, this could result in effluent limits for TP that are artificially stringent, or which could allow the loading of TP to exceed that simulated in the modeling supporting the permits and the TMDL. For these reasons, EPA believes that it is impracticable to calculate appropriate average monthly and average weekly limits for TP, in this case. The effluent limits for TP are therefore stated as seasonal average effluent limits.

The seasonal average TP effluent limits are identical to the seasonal average TP loads simulated in the modeling supporting the permits and the TMDL (see Table 4, above).

#### Reporting Requirements for Seasonal Average Limits

The permits include additional reporting requirements to ensure that water quality standards are attained. These include reporting the monthly average and maximum weekly average total phosphorus loads and concentrations on the monthly DMRs for February – October, inclusive, reporting the partial seasonal average load partial seasonal average phosphorus load for February 1st through the last day of the monitoring month, inclusive, for February – September, and, if the partial seasonal average phosphorus load is greater than the seasonal effluent limit, the permittee must submit a written report with the DMR, explaining the steps that the permittee will take to reduce its discharge of total phosphorus in order to achieve compliance with the seasonal average effluent limit by October 31<sup>st</sup>.

If the permittee ceases discharge to the river for at least three days during the season during which seasonal average limits apply, the permittee may include zero pounds per day values in the calculation of the partial seasonal average phosphorus load as specified in Attachment A of the draft permit. The purpose of Attachment A is to ensure that periods of zero discharge are given the same weight as the periods of time when the permittee is discharging, in the calculation of the seasonal average discharge. The number of zeros allowed for averaging is equal to the required sampling frequency of three times per week (0.429 samples per day), multiplied by the number of days of zero discharge, and rounded down to the nearest whole number.

#### ***Calculating Average Monthly Effluent Limits for CBOD<sub>5</sub> and Ammonia***

Seasonal average effluent limits are not appropriate for all of the oxygen demanding pollutants in these permits if they can be directly toxic or have effects on dissolved oxygen which are more directly related to short-term maximum loading. The Chesapeake Bay Memo states that the rationale it provides for annual average limits for TP and total nitrogen “does not apply to parameters other than nitrogen and phosphorus that may exhibit an oxygen demand to waters of the bay. Such parameters include dissolved oxygen, biochemical oxygen demand, and ammonia” (Page 2).

In addition to exhibiting an oxygen demand, ammonia can be directly toxic to aquatic life at high concentrations. In order to prevent acute toxicity to aquatic life, the *Technical Support Document for Water Quality-Based Toxics Control* (EPA/505/2-90-001) or TSD recommends that effluent limits for pollutants which may be toxic to aquatic life be expressed as average monthly and maximum daily limits, because even an average weekly limit has an averaging period that is too long to ensure that acute toxicity is prevented (see TSD at section 5.2.3). Maximum daily limits are not necessary for HARSB and Post Falls because, as described in

Appendix D, EPA has determined that discharges of ammonia at the proposed average weekly limits will not cause or contribute to excursions above water quality criteria for ammonia, for toxicity (IDAPA 58.01.02.283). However, expressing the ammonia limits exclusively as seasonal average limits could allow maximum daily or weekly average ammonia loads high enough to cause toxicity. Therefore, effluent limits for ammonia, for HARSB and Post Falls are expressed as average monthly and average weekly limits, consistent with 40 CFR 122.45(d)(2).

Effluent limits for ammonia, for the City of Coeur d'Alene, are expressed as a combination of seasonal average, average monthly, and maximum daily effluent limits. The seasonal average limit is based on meeting water quality standards for dissolved oxygen in the State of Washington, downstream from the point of discharge and is identical to the seasonal average modeled loading of ammonia in Table 4, above. The average monthly and maximum daily limits are based on Idaho water quality standards that are intended to prevent acute and chronic toxicity from ammonia, near the point of discharge. The use of average monthly limits in combination with maximum daily limits, when effluent limits are based on preventing toxicity to aquatic life, is consistent with the recommendations of the TSD (Section 5.2.3). It is impracticable to prevent acute toxicity using an average weekly limit. Therefore, the structure of City of Coeur d'Alene's effluent limits for ammonia is consistent with 40 CFR 122.45(d)(2) and with EPA guidance. The calculation of the toxicity-based ammonia limits for the City of Coeur d'Alene is explained in the City of Coeur d'Alene's fact sheet.

While CBOD<sub>5</sub> is not directly toxic, it has a more direct and immediate effect on dissolved oxygen concentrations than does TP. TP discharges result in an oxygen demand due to growth and ultimately decay of excess algae and other aquatic plants (see the Chesapeake Bay Memo at Page 3, footnote 2), but CBOD<sub>5</sub> begins to exert an oxygen demand at a roughly constant (first order kinetic) rate immediately upon being discharged to a receiving water. Furthermore, POTWs must meet technology-based effluent limits for CBOD<sub>5</sub>, which are stated as maximum 30- and 7-day concentrations, and a minimum 30-day average removal rate (40 CFR 133.102(a)(4)). Effluent limits for CBOD<sub>5</sub>, for continuous discharges, are therefore expressed as average monthly and average weekly limits, consistent with 40 CFR 122.45(d)(2).

As stated in Section 5.3.1 of the TSD, when the averaging periods for effluent limits differ from those of the water quality criterion or the wasteload allocation, it is necessary to use statistics to develop permit limits that comply with the regulations governing the expression of effluent limitations and consider effluent variability, while ensuring a low probability that the criterion or allocation will be exceeded.

Since the assumed loads from the TMDL modeling scenarios are seasonal average values applicable for an eight or nine month period, EPA will consider the assumed loading values above to be long term averages. In Table 5-2, the TSD provides a formula for calculating an average monthly permit limit that is consistent with a long term average wasteload allocation. The average monthly limit is a function of the CV and the sampling frequency.

#### Coefficient of Variation (CV)

Because these treatment facilities must be upgraded in order to achieve the proposed effluent limitations for TP, historic effluent variability for CBOD<sub>5</sub> and ammonia may not be representative of future effluent variability. Therefore, EPA has assumed that the CV is equal to 0.6, consistent with the recommendation of the TSD when effluent data are not available (see TSD at Page E-3).

Sampling Frequency

EPA proposes a sampling frequency of three times per week, for all three Idaho dischargers, for CBOD<sub>5</sub> and ammonia. This will result in at least 12 samples per month for each of these parameters. The TSD recommends using the actual required sampling frequency in effluent limit calculations, unless the actual frequency is less than four samples per month (see TSD at Section 5.5.3).

Probability Basis

The TSD recommends the use of the 95<sup>th</sup> percentile probability basis (5% exceedance probability) for the average monthly limit (see TSD at section 5.5.4). EPA has used the 95<sup>th</sup> percentile probability basis to establish average monthly limits for CBOD<sub>5</sub> and ammonia, consistent with the recommendations of the TSD.

Average Monthly Limits for CBOD<sub>5</sub> and Ammonia Based on Washington Water Quality Standards

Using the equation shown in Table 5-2 of the TSD, and the CVs and probability basis described above, EPA has calculated the average monthly limits shown in Table 6, below. Spreadsheets showing the detailed calculations of the average monthly limits are available from EPA upon request.

<b>Table 6: Average Monthly Limits</b>				
<b>Source</b>	<b>Seasonal Average Load (lb/day)</b>	<b>CV</b>	<b>Multiplier</b>	<b>Average Monthly Limit (lb/day)</b>
<b>Ammonia (February – October unless otherwise noted)</b>				
Coeur d'Alene (March – June)	Coeur d'Alene's average monthly ammonia limits are based on Idaho's water quality standards. See Appendix E of the Coeur d'Alene fact sheet.			<b>649</b>
Coeur d'Alene (July – September)				<b>330</b>
Coeur d'Alene (October)				<b>525</b>
HARSB	77.4	0.6	1.31	<b>101</b>
Post Falls	255	0.6	1.31	<b>334</b>
<b>CBOD<sub>5</sub> (February – October unless otherwise noted)</b>				
Coeur d'Alene (Feb. – Mar.)	226	0.6	1.31	<b>295</b>
Coeur d'Alene (Apr. – Oct.)	203	0.6	1.31	<b>265</b>
HARSB (continuous discharge)	77.4	0.6	1.31	<b>101</b>
Post Falls	255	0.6	1.31	<b>334</b>

Average Weekly LimitsCBOD<sub>5</sub>

To calculate average weekly limits for CBOD<sub>5</sub>, EPA has used the same 1.6:1 (40:25) ratio between the average monthly limits and the average weekly limits as the technology-based effluent concentration limits (40 CFR 133.102(a)(4)).

*Ammonia*

Average weekly limits for ammonia were calculated by adapting the relationship shown in Table 5-3 of the TSD to an average weekly limit instead of a maximum daily limit, using the required sampling frequency, the 95<sup>th</sup> percentile probability basis for the average monthly limit, the 99<sup>th</sup> percentile probability basis for the average weekly limit, and the coefficients of variation shown in Table 6, above. The resulting average weekly limits for HARSB and Post Falls are shown in Table 7, below. Table 7 also shows the maximum daily limits for the City of Coeur d'Alene. A complete explanation of the maximum daily ammonia limits for the City of Coeur d'Alene can be found in Appendix E to the Coeur d'Alene fact sheet.

<b>Table 7: Maximum Daily and Average Weekly Limits for Ammonia</b>						
<b>Source</b>	<b>Average Monthly Limit (AML) (lb/day)</b>	<b>CV</b>	<b>Number of Samples per Month</b>	<b>Number of Samples per Week</b>	<b>Ratio</b>	<b>Average Weekly Limit (AWL) or Maximum Daily Limit (MDL) (lb/day)</b>
Coeur d'Alene (Mar. – June)	649	0.6	12	N/A	2.38	<b>1547 (MDL)</b>
Coeur d'Alene (July – Sep.)	330	0.6	12	N/A	2.38	<b>786 (MDL)</b>
Coeur d'Alene (Mar. – Oct.)	525	0.6	12	N/A	2.38	<b>1252 (MDL)</b>
HARSB	101	0.6	12	3	1.58	<b>160 (AWL)</b>
Post Falls	334	0.6	12	3	1.58	<b>528 (AWL)</b>

*Basis for Mass Limits*

The federal regulation 40 CFR 122.45(f)(1) requires that effluent limits be expressed in terms of mass, except for pollutants that cannot be properly expressed as mass (e.g. pH and temperature). Effluent limits for TP, ammonia, and CBOD<sub>5</sub> can be properly expressed as mass. Therefore, effluent limits for these parameters are, at a minimum, expressed in terms of mass.

Effluent limits for TP are expressed exclusively in terms of mass because there are no applicable technology-based standards or numeric in-stream water quality standards for TP, the effluent limitations for TP are intended to meet Washington water quality standards, which apply several miles downstream from the discharges after complete mixing has occurred, and phosphate phosphorus is neither directly toxic to aquatic life nor directly hazardous to human health. Therefore, there is no basis to express the water quality-based TP limits in units other than mass.

As explained below, CBOD<sub>5</sub> and ammonia are additionally limited in terms of other units of measurement.

*Basis for Concentration and Removal Rate Limits for CBOD<sub>5</sub> and Ammonia*

Pollutants which are limited in terms of mass may be additionally limited in terms of other units of measurement, and the permit shall require the permittee to comply with both limitations (40 CFR 122.45(f)(2)).

Applicable technology-based standards for CBOD<sub>5</sub> are expressed in terms of concentration and removal rate (40 CFR 133.102(a)(4)). Therefore, in addition to the water quality-based mass limits described above, the permits include additional technology-based effluent limits for CBOD<sub>5</sub>, which are expressed in terms of concentration (25 mg/L monthly average and 40 mg/L weekly average, 40 CFR 133.102(a)(4)(i – ii)) and a minimum removal rate of 85% (40 CFR 133.102(a)(4)(iii)).

The proposed concentration and removal rate limits for CBOD<sub>5</sub> are technology-based limits. The proposed mass limits for CBOD<sub>5</sub> are water quality-based limits.

For parameters which may be directly toxic to aquatic life, the TSD recommends that effluent limitations be expressed in terms of both concentration and mass for effluents discharging to waters with less than 100-fold dilution (see TSD at Section 5.7.1). The complete-mix dilution ratios, based on 7Q10 river flow rates and current treatment plant design flow rates, are as shown in Table 8:

<b>Table 8: Complete Mix Dilution Factors</b>				
<b>Current Design Flows (CFS)</b>				
Coeur d'Alene		9.3		
Hayden		3.7		
Post Falls		7.7		
Season	7Q10 (CFS)	Dilution Factors		
		CDA	HARSB	PF
July – Sept.	500	54	135	65
Oct. – June	1030	111	277	133

From July – September, under critical low flow conditions, the complete-mix dilution factor is less than 100:1 for Coeur d'Alene and Post Falls. Therefore, effluent limits for ammonia, which can be directly toxic to aquatic life, are expressed in terms of both mass and concentration, from July – September, for Coeur d'Alene and Post Falls. From October – June, the complete-mix dilution factors are greater than 100:1 for all three Idaho dischargers. Therefore, concentration limits for ammonia are generally not necessary during this time.

However, from November – January, to ensure compliance with the anti-backsliding provisions of the Clean Water Act, concentration limits are included in the draft reissued permits for HARSB and Post Falls because such limits were in the prior permits.

Effluent limits for POTWs must generally be calculated based on design flow (40 CFR 122.45(b)(1)). The relationship between the concentration and mass limits is therefore calculated using the following equation:

$$\text{Concentration limit (mg/L or parts per million)} = \text{mass limit (lb/day)} \div [8.34 \text{ lb/gallon} \times \text{design flow (mgd)}]$$

### ***Proposed Effluent Limits Summary***

The effluent limits for TP, CBOD<sub>5</sub>, and ammonia that are derived from and comply with the applicable water quality standards of Idaho and Washington are as follows:

Table 9: Proposed Effluent Limits for TP, CBOD <sub>5</sub> and ammonia				
Parameter	Units	Effluent Limits		
		Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit
Proposed Effluent Limits for the City of Coeur d'Alene				
TP as P (Feb. – Oct.)	lb/day	3.17 seasonal average		
TP as P (Nov. – Jan.)	lb/day	Phosphorus management plan. See permit at Part II.C.		
CBOD <sub>5</sub> (November – January)	mg/L	25	40	—



Table 9: Proposed Effluent Limits for TP, CBOD <sub>5</sub> and ammonia				
Parameter	Units	Effluent Limits		
		Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit
		lb/day	1251	2002
CBOD <sub>5</sub> (February – March)	% removal	85% min.	—	—
	mg/L	25	40	—
	lb/day	295	472	—
	% removal	85% min.	—	—
CBOD <sub>5</sub> (April – October)	mg/L	25	40	—
	lb/day	265	424	—
	% removal	85% min.	—	—
	Ammonia (March – June)	lb/day	649	—
Ammonia (July – September)	mg/L	6.59	—	15.7
	lb/day	330	—	786
Ammonia (March – June and October)	lb/day	525	—	1252
Ammonia (November – February)	No limits. Monitor and report only.			
Proposed Effluent Limits for the City of Post Falls				
TP as P (Feb – Oct.)	lb/day	3.19 seasonal average		
TP as P (Nov. – Jan.)	lb/day	Phosphorus management plan. See permit at Part II.C.		
CBOD <sub>5</sub> (November – January)	mg/L	25	40	—
	lb/day	1043	1668	—
	% removal	85% min.	—	—
	CBOD <sub>5</sub> (February – October)	mg/L	25	40
lb/day		334	534	—
% removal		85% min.	—	—
Ammonia (February – June and October)		lb/day	334	528
	Ammonia (July – September)	mg/L	8.00	12.7
lb/day		334	528	—
Ammonia (November – January)	mg/L	17.7	—	63.8
	lb/day	737	—	2661
Proposed Effluent Limits for the Hayden Area Regional Sewer Board				
TP as P (Feb. – Oct.)	lb/day	1.33		
TP as P (Nov. – Jan.)	lb/day	Phosphorus management plan. See permit at Part II.C.		
CBOD <sub>5</sub> (November – January)	mg/L	25	40	—
	lb/day	500	801	—
	% removal	85% min.	—	—
	CBOD <sub>5</sub> (February – October when discharging continuously)	mg/L	25	40
lb/day		101	162	—
% removal		85% min.	—	—
CBOD <sub>5</sub> (February – October when not discharging continuously)		mg/L	25	40
	lb/day	77.4 seasonal average		
	% removal	85% min.	—	—
	Ammonia (February – October)	lb/day	101	160

<b>Table 9: Proposed Effluent Limits for TP, CBOD<sub>5</sub> and ammonia</b>				
Parameter	Units	Effluent Limits		
		Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit
Ammonia (November – January)	mg/L	49.2	—	156
	lb/day	985	—	3128

***Comparison of Proposed Effluent Limits to the Corresponding Limits in the 2007 Draft Permits***

The following nine figures provide a comparison of the phosphorus, ammonia, and CBOD<sub>5</sub> limits in the current draft permits to the corresponding effluent limits in the 2007 draft permits. Note that the 2007 draft permits did not propose effluent limits for TP in February, whereas the current draft permits do propose such limits.

**Figure 1**




Figure 2




Figure 3




Figure 4




Figure 5




Figure 6




Figure 7




Figure 8





Figure 9



## F. Effect of the Proposed Effluent Limits

### *Lake Spokane*

As explained above, modeling shows that the proposed effluent limits for TP, CBOD<sub>5</sub> and ammonia, considered cumulatively with the effluent limits for Washington point sources in their NPDES permits and the load allocations for Washington non-point sources and the DO improvements required of Avista in the DO TMDL, will ensure compliance with Washington's water quality criterion for DO in Lake Spokane.

### *State Line*

The memoranda from Portland State University and LimnoTech do not specifically analyze the effect of the proposed effluent limits at the state line. Therefore, as explained below, EPA has analyzed the model output and determined that, in compliance with 40 CFR 122.4(d) and 40 CFR 122.44(d)(4), the proposed effluent limits for the Idaho point sources will ensure that Washington's and Idaho's water quality standards are met at the state line.

### Dissolved Oxygen

Even with zero discharge of human-caused pollution in Idaho, Washington's numeric criterion for dissolved oxygen (8.0 mg/L) would only be attained at the state line about 96% of the time. However, this does not mean that Washington's water quality standards would not be attained the remaining 4% of the time, because, at times, the natural DO concentration at the state line is less than 8.0 mg/L. Washington's water quality standards state that, "when a water body's DO is lower than the (numeric) criteria...(or within 0.2 mg/L of the criteria) and that condition is due to natural conditions, then human actions considered cumulatively may not cause the DO of that water body to decrease more than 0.2 mg/L" (WAC 173-201A-200(1)(d)(i)).

At times when the model predicts that DO is less than 8.2 mg/L (i.e., within 0.2 mg/L of the numeric criterion), with zero discharge of human-caused pollution in Idaho, the maximum DO decrease attributable to the Idaho dischargers, including stormwater discharges, at the state line, is 0.13 mg/L below natural conditions, which is less than the decrease allowed by the standards (0.2 mg/L). Therefore, the effluent limits will ensure compliance with Washington's water quality standards for dissolved oxygen at the state line.

In Idaho, in waters designated for salmonid spawning, the applicable numeric dissolved oxygen criterion is 6.0 mg/L or 90% of saturation, whichever is greater. Modeling predicts that, under the proposed effluent limits, the DO concentration at the state line will be greater than 6.0 mg/L at all times (the minimum DO is 7.65 mg/L). The dissolved oxygen concentration will be greater than 90% of saturation, 99.96% of the time, under both the no source and effluent limit scenarios. Therefore, the effluent limits will ensure compliance with Idaho's numeric DO criteria 99.96% of the time, and the very infrequent excursions below the numeric criteria (0.04% of the time) occur due to natural background conditions and do not violate Idaho's water quality standards (see IDAPA 58.01.02.200.09).

### pH

The Washington pH criterion for the Spokane River at the state line is "pH shall be within the range of 6.5 to 8.5 with a human-caused variation within the above range of less than 0.5 units"

(WAC 173-201A, Table 200(1)(g)). Idaho's water quality standard is "within the range of six point five (6.5) to nine point zero (9.0)" (IDAPA 58.01.02.250.01.a).

Under the proposed effluent limits, the predicted minimum and maximum pH at the state line are 7.12 and 7.96 standard units, respectively, which complies with the criteria for pH range for both Idaho and Washington. The maximum human-caused pH changes are an increase of 0.21 standard units, and a decrease of 0.26 standard units, which is less than the 0.5 unit human-caused variation allowed by the Washington standards. Therefore, the proposed effluent limits ensure compliance with both Washington's and Idaho's water quality standards for pH, at the state line.

### Phosphorus

Neither Idaho nor Washington has statewide numeric water quality criteria for TP. However, Idaho does have a narrative criterion for nutrients (IDAPA 58.01.02.200.06), and the Spokane River is 303(d) listed for TP in Idaho. EPA has a Clean Water Act Section 304(a) recommended water quality criterion for TP, for the western forested mountains ecoregion, which is 10 µg/L (EPA 822-B-00-015, Table 2). The criteria document recommends that nutrient criteria be applied using a seasonal or annual averaging period (Page 6).

The model predicts that, with the proposed effluent limits in place, the median TP concentration at the state line, from February through October, will be 9.1 µg/L. This is less than the EPA-recommended criterion for TP, for this ecoregion, which is 10.0 µg/L (EPA 2000). The model predicts that the proposed effluent limits will result in only a 0.8 µg/L increase relative to the February – October median TP concentration predicted under the "no source" scenario (i.e., with no discharge from any Idaho point sources, including storm water). The concentration of TP at the State line, from February through October, will be less than 10 µg/L 55% of the time, with the proposed effluent limits in place. Therefore, the effluent limits proposed in the draft permits will ensure compliance with Idaho's and Washington's narrative criteria for nutrients and aesthetics (IDAPA 58.01.02.200.06, WAC 173-201A-260(2)(b)).

### Temperature

The Washington water quality standard for temperature in the Spokane River at the state line is: "Temperature shall not exceed a 1-DMax of 20.0°C due to human activities. When natural conditions exceed a 1-DMax of 20.0°C no temperature increase will be allowed which will raise the receiving water temperature by greater than 0.3°C; nor shall such temperature increases, at any time exceed  $t=34/(T+9)$ " (WAC 173-201A-602).

The capital "T" represents the background temperature as measured at a point or points unaffected by the discharge and representative of the highest ambient water temperature in the vicinity of the discharge (WAC 173-201A-200(1)(c)(ii)(A)). The maximum "no source" temperature (i.e. the temperature with no discharge from any Idaho point sources) at the state line is 26.4 °C; the value of  $34/(T + 9)$  therefore equals 0.96 °C. The maximum temperature increase attributable to the Idaho dischargers, at any time, is 0.27 °C, which is much less than the allowable increase (0.96 °C). At times when the predicted temperature, under the "no source" scenario, is greater than or equal to 20 °C, the maximum temperature increase attributable to the Idaho point sources is 0.13 °C, less than half the increase allowed by the criterion (0.3 °C).

Therefore, the Idaho dischargers do not have the reasonable potential to cause or contribute to excursions above water quality standards for temperature in the State of Washington, and it is not



necessary to include effluent limits for temperature in these permits, in order to ensure compliance with Washington's water quality criteria for temperature.

Furthermore, EPA has determined that the Idaho dischargers do not have the reasonable potential to cause or contribute to excursions above water quality standards for temperature, in waters of the State of Idaho (Nickel 2007, 2011). Therefore, the permits do not require water quality-based effluent limits for temperature.

#### Ammonia

The model predicts that, under the proposed ammonia effluent limits, the maximum instantaneous concentration of ammonia at the state line will be 0.42 mg/L, which is less than either State's chronic numeric water quality criteria for ammonia, under critical conditions for temperature and pH. Thus, the effluent limits in the draft permits will ensure compliance with both States' numeric water quality criteria for ammonia, at the state line.

EPA has determined that the proposed effluent limits for ammonia will ensure compliance with Idaho's water quality standards for ammonia, after mixing with less than 25% of the critical receiving stream flow, in accordance with Idaho's mixing zone policy (IDAPA 58.01.02.060). Therefore, it is not necessary to establish more stringent water quality-based effluent limits for ammonia, for the purpose of meeting Idaho's water quality standards in the near field.

#### ***The State of Washington's Antidegradation Policy***

In addition to ensuring compliance with the State of Washington's water quality criteria, the draft permits for the City of Coeur d'Alene, City of Post Falls, and Hayden Area Regional Sewer Board ensure compliance with the State of Washington's antidegradation requirements (WAC 173-201A-300 – 330).

In the State of Washington, the Spokane River is currently 303(d) listed for dissolved oxygen, lead, temperature, total dissolved gas, 2,3,7,8 TCDD, and PCBs. The Spokane River is therefore not of higher quality than the applicable water quality criteria for these parameters. Therefore, the affected waters of the State of Washington are not afforded "Tier II" antidegradation protection under WAC 173-201A-320, for these parameters.

The Spokane River and Lake Spokane are 303(d)-listed for DO in the State of Washington. Washington's antidegradation policy states that "for waters that do not meet assigned criteria, or protect existing or designated uses, the department will take appropriate and definitive steps to bring the water quality back into compliance with the water quality standards." As explained above, the effluent limits for TP, CBOD<sub>5</sub>, and ammonia ensure compliance with Washington's water quality criteria for dissolved oxygen. The permits contain effluent limits that ensure compliance with Idaho's water quality criteria for lead (which are more stringent than Washington's criteria) at the end-of-pipe. Thus, the lead limits are also stringent enough to ensure compliance with Washington's water quality criteria for lead. Furthermore, as explained above, these discharges do not have the reasonable potential to cause or contribute to excursions above Washington's water quality criteria for temperature. Washington's EPA-approved water quality criteria for these parameters ensure that existing and designated uses are maintained and protected, thereby ensuring compliance with Washington's Tier I antidegradation requirements (WAC 173-201A-310).

No antidegradation analysis is necessary for PCBs or 2,3,7,8 TCDD because the Idaho permits do not contain effluent limits for these parameters and there is no information demonstrating that the Idaho permittees discharge these parameters. Therefore the discharges do not allow lower water quality due to these pollutants. The permits include monitoring requirements for PCBs and 2,3,7,8 TCDD. The monitoring data will be used to determine if the discharges have the reasonable potential to cause or contribute to excursions above water quality standards for PCBs or 2,3,7,8 TCDD. Available data indicate that the Spokane River does not exceed either State's Clean Water Act effective PCB criterion at the State line (Serdar et al. 2011).<sup>3</sup>

For other parameters, in general, the effluent limits in the draft permits are as stringent as or more stringent than the corresponding effluent limits in the previous permits. In those cases, the permits are not new or expanded relative to the 1999 permits, thus they will not cause a lowering of water quality under Washington's Tier II antidegradation provisions (WAC 173-201A-320).

The Spokane River has not been designated an outstanding resource water. Therefore, the Tier III antidegradation protections of WAC 173-201A-330 do not apply to the Spokane River.

### **Summary**

The effluent limits that EPA is proposing for TP, ammonia and CBOD<sub>5</sub> ensure a level of water quality that is derived from and complies with the applicable water quality standards of the States of Idaho and Washington, for dissolved oxygen, pH, ammonia, and nutrients, based on the cumulative impact of all human actions. Therefore, the level of water quality to be achieved by these effluent limits is derived from and complies with the applicable water quality standards of the States of Washington and Idaho, in compliance with federal regulations (40 CFR 122.4(d), 122.44(d)(1)(vii)(A), 122.44(d)(4)).

### **G. References**

Cope, Ben. 2006. *Draft Assessment of the Water Quality Impact of Idaho Wastewater Treatment Plants on the Spokane River and Lake Spokane*. US EPA Region 10. Office of Environmental Assessment. July 2006.

Dilks, D. and J. Helfand. 2009. "Results of CE-QUAL-W2 Model Sensitivity Analyses in Response to Different Levels of Idaho Point Source Discharge."

EPA. 1991. *Technical Support Document for Water Quality-based Toxics Control*. US Environmental Protection Agency. Office of Water. EPA/505/2-90-001. March 1991.

EPA. 2004. Memorandum from James A. Hanlon to John Capacasa and Rebecca Hanmer. Subject: Annual Permit Limits for Nitrogen and Phosphorus for Permits Designed to Protect Chesapeake Bay and its tidal tributaries from Excess Nutrient Loading under the National Pollutant Discharge Elimination System. March 3, 2004.

EPA. 2008. Municipal Nutrient Removal Technologies Reference Document. US Environmental Protection Agency. Office of Wastewater Management. EPA 832-R-08-06. September 2008.

---

<sup>3</sup> Washington's PCB criterion is identical to the criterion that is in effect for Clean Water Act purposes in Idaho.

HDR. 2009. Memorandum from David Clark and Michael Kasch. Subject: Spokane River CE-QUAL-W2 Model Discharger Total Phosphorus Simulations with Variable Effluent Concentration. June 24, 2009. Revised December 2, 2009.

LimnoTech. 2010. Memorandum from David Dilks to Brian Nickel and Ben Cope. Subject: Recent Issue with Spokane CE-QUAL-W2 Model. Memorandum from David Dilks to Brian Nickel and Ben Cope. December 28, 2010.

LimnoTech. 2011. Memorandum from David Dilks and Joseph Helfand to Doug Krapas. Subject: Documentation of Alternate Spokane River TMDL Scenario – with Alternate Seasonal Limits for Inland Empire Paper. May 18, 2011.

Nickel, Brian. 2007. *Temperature Reasonable Potential Analysis for Dischargers to the Spokane River in Idaho*. February 5, 2007. US EPA Region 10. Office of Water and Watersheds.

Nickel, Brian. 2011. *Updated Temperature Reasonable Potential Analysis for Dischargers to the Spokane River in Idaho*. <DATE>. US EPA Region 10. Office of Water and Watersheds.

Portland State University. 2010. *Spokane River Modeling Final Scenarios Report 2010*. Water Quality Research Group. Department of Civil and Environmental Engineering. Maseeh College of Engineering and Computer Science. Technical report EWR-01-10.

Reynolds, D. and D. Clark. 2005. “Technical Memorandum: Evaluation of Exemplary WWTPs Practicing High Removal of Phosphorus.” Spokane River TMDL Collaboration, Technical Working Group. CH2M Hill project number 329766.01.01. November 21, 2005.

Spokane River DO TMDL Collaboration Flows and Loadings Workgroup. 2005. Memorandum to Steering Group and Full Group. Subject: Flows and Loadings. September 19, 2005.

## Appendix C: General Basis for Effluent Limits

The following discussion explains in more detail the statutory and regulatory bases for the technology and water quality-based effluent limits in the draft permit. Part A discusses technology-based effluent limits, Part B discusses water quality-based effluent limits in general, and Part C discusses facility specific effluent limits.

### A. Technology-Based Effluent Limits

#### *Federal Secondary Treatment Effluent Limits*

In sections 301(b)(1)(B) and 304(d)(1), the CWA established a performance level, referred to as “secondary treatment,” which all POTWs are required to meet. EPA developed and promulgated “secondary treatment” regulations that are found in 40 CFR 133.102. These technology-based limits identify the minimum level of effluent quality attainable by secondary treatment in terms of five-day biochemical oxygen demand (BOD<sub>5</sub>) or five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), and pH.

The regulations allow effluent limits for oxygen demanding material to be expressed as either BOD<sub>5</sub> or CBOD<sub>5</sub>, at the option of the permitting authority. EPA has chosen to express the effluent limits in terms of CBOD<sub>5</sub> in this case. The federally promulgated secondary treatment effluent limits are listed in Table C-1.

<b>Table C-1: Secondary Treatment Effluent Limits (40 CFR 133.102)</b>			
<b>Parameter</b>	<b>Average Monthly Limit</b>	<b>Average Weekly Limit</b>	<b>Range</b>
CBOD <sub>5</sub>	25 mg/L	40 mg/L	—
TSS	30 mg/L	45 mg/L	—
Removal Rates for CBOD <sub>5</sub> and TSS	85% (minimum)	—	—
pH	—	—	6.0 – 9.0 s.u.

EPA has determined that the secondary treatment CBOD<sub>5</sub> effluent limits are adequately stringent to protect water quality in the States of Idaho and Washington from November through January. From February through October, more stringent water quality-based CBOD<sub>5</sub> effluent limits apply (see Appendix B).

EPA has determined that the secondary treatment TSS limits are adequately stringent to protect water quality in the Spokane River at all times, therefore, the TSS limits in the draft permit are the secondary treatment limits.

EPA has determined that the secondary treatment pH effluent limits are not stringent enough to protect water quality in the Spokane River. Therefore, more stringent water quality-based pH effluent limits apply.

#### *Chlorine*

The Post Falls facility generally uses ultraviolet disinfection in lieu of chlorine. Therefore, there are no technology-based chlorine limits that are applicable to the discharge.

***Mass-Based Limits***

Effluent limits are generally calculated on a concentration basis. The federal regulation at 40 CFR 122.45(f) generally requires that effluent limits be expressed in terms of mass. The regulation at 40 CFR 122.45(b)(1) requires that effluent limitations for POTWs be calculated based on the design flow of the facility. The mass based limits are expressed in pounds per day and are generally calculated from the corresponding concentration limits as follows:

Mass based limit (lb/day) = concentration limit (mg/L or ppm) × design flow (mgd) × 8.34<sup>1</sup>

One exception to this method of calculating mass effluent limits is for lead and zinc. For these pollutants, the mass limits are identical to the mass limits in the prior permit, even though the design flow of the POTW has increased from 3.48 mgd at the time the prior permit was issued, to 5 mgd. This is based on a stipulation of Idaho DEQ's draft Clean Water Act Section 401 certification, which requires that the total mass of pollutants causing water quality impairments remain constant or decrease within the watershed, consistent with IDAPA 58.01.02.055.04.

From February – October, the mass limits for CBOD are calculated independently of the concentration limits. The concentration limits are technology-based at all times. The mass limits are water quality-based from February – October and technology-based from November – January.

**B. Water Quality-based Effluent Limits*****Statutory and Regulatory Basis***

Section 301(b)(1)(C) of the CWA requires the development of limitations in permits necessary to meet water quality standards. Discharges to State or Tribal waters must also comply with limitations imposed by the State or Tribe as part of its certification of NPDES permits under section 401 of the CWA. Federal regulations at 40 CFR 122.4(d) prohibit the issuance of an NPDES permit when the imposition of conditions in that permit cannot ensure compliance with the water quality standards of all affected States, which may include downstream States. The NPDES regulation 40 CFR 122.44(d)(1) implementing Section 301(b)(1)(C) of the CWA requires that permits include limits for all pollutants or parameters which are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any State or Tribal water quality standard, including narrative criteria for water quality. Effluent limits must also meet the standards of affected States other than the State in which the discharge originates (40 CFR 122.4(d), 122.44(d)(4), see also CWA Section 401(a)(2)).

The regulations require the permitting authority to make this evaluation using procedures which account for existing controls on point and nonpoint sources of pollution, the variability of the pollutant in the effluent, species sensitivity (for toxicity), and where appropriate, dilution in the receiving water. The limits must be stringent enough to ensure that water quality standards are met, and must be consistent with any available wasteload allocation for the discharge in an approved TMDL.

---

<sup>1</sup> 8.34 is the density of water, in units of pounds per gallon.

***Reasonable Potential Analysis***

When evaluating the effluent to determine if water quality-based effluent limits are needed based on numeric criteria, EPA projects the receiving water concentration (downstream of where the effluent enters the receiving water) for each pollutant of concern. EPA uses the concentration of the pollutant in the effluent and receiving water and, if appropriate, the dilution available from the receiving water, to project the receiving water concentration. If the projected concentration of the pollutant in the receiving water exceeds the numeric criterion for that specific chemical, then the discharge has the reasonable potential to cause or contribute to an excursion above the applicable water quality standard, and a water quality-based effluent limit is required.

***Mixing Zones***

Sometimes it is appropriate to allow a small area of the receiving water to provide dilution of the effluent. These areas are called mixing zones. Mixing zone allowances will increase the mass loadings of the pollutant to the water body, and decrease treatment requirements. Mixing zones can be used only when there is adequate receiving water flow volume and the receiving water meets the criteria necessary to protect the designated uses of the water body. Mixing zones are authorized by the Idaho Department of Environmental Quality (IDEQ). Based on IDEQ's draft Clean Water Act Section 401 certification, some of the water quality-based effluent limits in this permit have been calculated using a mixing zone. Effluent limit and reasonable potential calculations for cadmium, lead, and zinc did not use mixing zones because the receiving water does not meet water quality standards for those pollutants. If IDEQ does not authorize mixing zones in the final Clean Water Act Section 401 certification for certain parameters, the water quality-based effluent limits for those parameters will be recalculated such that the criteria are met before the effluent is discharged to the receiving water.

***Procedure for Deriving Water Quality-based Effluent Limits***

The first step in developing a water quality-based effluent limit is to develop a wasteload allocation (WLA) for the pollutant. A wasteload allocation is the concentration or loading of a pollutant that the permittee may discharge without causing or contributing to an excursion above water quality standards in the receiving water.

In cases where a mixing zone is not authorized (for lead and zinc, in this case), either because the receiving water already exceeds the criterion, the receiving water flow is too low to provide dilution, or the State does not authorize one, the criterion becomes the WLA. Establishing the criterion as the wasteload allocation ensures that the permittee will not cause or contribute to an excursion above the criterion. The following discussion details the specific water quality-based effluent limits in the draft permit.

Once a WLA is developed, EPA calculates effluent limits which are protective of the WLA using statistical procedures described in Appendix E.

### C. Facility-Specific Limits

#### *pH*

The most stringent water quality criteria for pH are for the protection of aquatic life uses. The “aquatic life” pH criteria state that the pH must be no less than 6.5 and no greater than 9.0 standard units.

The permittee has collected pH and alkalinity data for the effluent. EPA obtained pH and alkalinity data for the receiving water from the USGS. EPA has used these data to determine the discharge’s effects on the pH of the receiving water. EPA believes that a mixing zone for pH is appropriate.

The proposed pH limits are 6.3 to 9.0 from October through June and 6.4 to 9.0 from July through September. If IDEQ does not grant a mixing zone for pH in its final CWA Section 401 certification, EPA will change the pH limits to a range of 6.5 to 9.0 standard units year round, thus requiring that the pH criteria are met before the effluent is discharged to the receiving water. See Appendix F for effluent limit calculations for pH.

#### *Total Phosphorus*

EPA has determined that the phosphorus in the permitted discharge, together with the discharges of phosphorus from the Hayden Area Regional Sewer Board and the City of Coeur d’Alene as well as municipal stormwater discharged to the Spokane River in Idaho, has the reasonable potential to cause or contribute to excursions above water quality criteria dissolved oxygen in the State of Washington, downstream of the discharge. EPA has calculated water quality-based effluent limits for total phosphorus which ensure a level of water quality that is derived from and complies with the applicable water quality requirements of both Washington and Idaho. See Appendix B for a complete discussion of the calculation of water quality-based effluent limits for total phosphorus.

#### *Ammonia*

As explained in Appendix B, EPA has determined that, independent of any concerns about the Post Falls facility’s discharge of ammonia causing or contributing to excursions above water quality standards for ammonia in waters of the State of Idaho, the Post Falls facility’s discharge of ammonia, in combination with other sources of oxygen-demanding pollution, has the reasonable potential cause or contribute to nonattainment of Washington’s water quality standards for dissolved oxygen (DO), from February – October. Therefore effluent limits are necessary for ammonia, from February – October, in order to ensure compliance with Washington’s water quality standards for DO. EPA has determined that the ammonia effluent limits that are necessary to meet Washington’s water quality standards for DO, which apply from February – October, will also ensure compliance with Idaho’s numeric water quality criteria for ammonia.

During November – January, EPA has determined that the ammonia effluent concentration (i.e., mg/L) limits that were in the 1999 permit will ensure compliance with Idaho’s numeric water quality criteria for ammonia, even if the facility is discharging at its new, higher design flow rate of 5 mgd. Therefore, these limits have been carried forward in the draft permit, consistent with the anti-backsliding provisions of the Clean Water Act (§§ 303(d)(4) and 402(o)). EPA has re-

calculated the mass effluent limits for ammonia, for November – January, based on the increased design flow of the POTW (40 CFR 122.45(b)(1)). The revised mass limits are less stringent than those in the prior permit, in proportion to the increased design flow of the POTW. The increased design flow of the POTW is a material and substantial alteration or addition to the permitted facility, which provides an exception to the anti-backsliding provisions of the Clean Water Act (Section 402(o)(2)(A)).

#### ***Five-Day Carbonaceous Biochemical Oxygen Demand***

As stated above, EPA has promulgated technology-based effluent limits for CBOD<sub>5</sub>. The technology-based limits apply from November through January.

However, EPA has determined that, from February through October, more stringent mass effluent limits are necessary for CBOD<sub>5</sub>, in order to ensure compliance with water quality criteria for dissolved oxygen in the State of Washington. The concentration and removal rate limits remain technology-based, year-round. See Appendix B for a complete discussion of the basis water quality-based effluent limits for CBOD<sub>5</sub> for March February – October.

#### ***Metals***

The 1999 permit included effluent limits for lead and zinc year-round and for copper from July – September. EPA has determined that the effluent limits for lead and zinc are stringent enough to ensure compliance with water quality standards for those parameters. Therefore, EPA has maintained the prior permit's concentration limits for these parameters under the anti-backsliding provisions of the Clean Water Act. EPA has not changed the prior permit's mass limits for these parameters based on the increased design flow of the POTW, because Idaho water quality rules require that the total loading of pollutants causing water quality limited listings must remain constant or decrease within the watershed (IDAPA 58.01.02.055.04).

EPA has determined that the prior permit's concentration effluent limits for copper will ensure compliance with water quality standards for copper, even when discharging at the new, higher design flow rate of 5 mgd. Therefore the prior permit's concentration effluent limits, which were applicable from July – September, have been continued forward under the anti-backsliding provisions of the Clean Water Act. EPA has re-calculated the mass effluent limits for copper, for July – September, based on the increased design flow of the POTW (40 CFR 122.45(b)(1)). The revised mass limits are less stringent than those in the prior permit, in proportion to the increased design flow of the POTW. The increased design flow of the POTW is a material and substantial alteration or addition to the permitted facility, which provides an exception to the anti-backsliding provisions of the Clean Water Act (Section 402(o)(2)(A)).

EPA has determined that the discharge does not have the reasonable potential to cause or contribute to excursions above water quality standards for copper from October – June. Therefore, no effluent limits are proposed for copper for October – June.

#### ***E. Coli***

The Idaho water quality standards state that waters of the State of Idaho that are designated for recreation are not to contain E. coli bacteria in concentrations exceeding a geometric mean of 126 organisms per 100 ml based on a minimum of five samples taken every three to seven days over a thirty day period. Therefore, the draft permit contains a monthly geometric mean effluent



limit for E. coli of 126 organisms per 100 ml, and a minimum sampling frequency of five grab samples per month (IDAPA 58.01.02.251.01.a.).

The Idaho water quality standards also state that a water sample that exceeds certain “single sample maximum” values indicates a likely exceedance of the geometric mean criterion, although it is not, in and of itself, a violation of water quality standards. For waters designated for primary contact recreation, the “single sample maximum” value is 406 organisms per 100 ml (IDAPA 58.01.02.251.01.b.ii.).

The goal of a water quality-based effluent limit is to ensure a low probability that water quality standards will be exceeded in the receiving water as a result of a discharge, while considering the variability of the pollutant in the effluent (see TSD at Section 5.3.1). Because a single sample value exceeding 406 organisms per 100 ml indicates a likely exceedance of the geometric mean criterion, EPA has imposed an instantaneous (single grab sample) maximum effluent limit for E. coli of 406 organisms per 100 ml, in addition to a monthly geometric mean limit of 126 organisms per 100 ml, which directly implements the water quality criterion for E. coli. This will ensure that the discharge will have a low probability of exceeding water quality standards for E. coli.

Regulations at 40 CFR 122.45(d)(2) require that effluent limitations for continuous discharges from POTWs be expressed as average monthly and average weekly limits, unless impracticable. The terms “average monthly limit” and “average weekly limit” are defined in 40 CFR 122.2 as arithmetic (as opposed to geometric) averages.

It is impracticable to properly implement a 30-day geometric mean criterion in a permit using monthly and weekly arithmetic average limits. The geometric mean of a given data set is equal to the arithmetic mean of that data set if and only if all of the values in that data set are equal. Otherwise, the geometric mean is always less than the arithmetic mean. In order to ensure that the effluent limits are “derived from and comply with” the geometric mean water quality criterion, as required by 40 CFR 122.44(d)(1)(vii)(A), it is necessary to express the effluent limits as a monthly geometric mean and an instantaneous maximum limit.

### ***Chlorine***

Although the Post Falls facility uses ultraviolet disinfection, the City has continued to monitor the effluent for chlorine, as required by its 1999 permit. The effluent data indicate that the facility has the reasonable potential to cause or contribute to excursions above water quality standards for chlorine if and only if chlorine is used in the treatment process. Therefore, the draft permit proposes water quality-based effluent limits for chlorine when chlorine is used in the treatment process. The facility does not have the reasonable potential to cause or contribute to excursions above water quality standards for chlorine when chlorine is not used in the treatment process, so no effluent limits are proposed when chlorine is not used in the treatment process.

**D. Summary of Limits and Bases**

The following table summarizes the general statutory and regulatory bases for the limits in the draft permit.

<b>Table C-3 Summary of Bases for Effluent Limits and BMP Requirements</b>	
<b>Limited Parameter</b>	<b>Basis for Limit</b>
CBOD <sub>5</sub> (concentration & removal rate)	Clean Water Act (CWA) Section 301(b)(1)(B), 40 CFR 133 (technology-based)
CBOD <sub>5</sub> (mass, November – January)	Clean Water Act (CWA) Section 301(b)(1)(B), 40 CFR 133, 40 CFR 122.45(b)(1), 122.45(f) (technology-based, mass limits)
CBOD <sub>5</sub> (mass, February – October)	CWA Section 301(b)(1)(C), 40 CFR 122.4(d), 40 CFR 122.44(d), WAC 173-201A-200(1)(d)(ii) (water quality-based, all affected States)
TSS	CWA Section 301(b)(1)(B), 40 CFR 133, 40 CFR 122.45(b)(1), 122.45(f) (technology-based, mass limits)
pH	CWA Section 301(b)(1)(C), 40 CFR 122.44(d), IDAPA 58.01.02.250.01.a, IDAPA 58.01.02.060 (water quality-based, with mixing zone)
Phosphorus (February – October)	CWA Section 301(b)(1)(C), 40 CFR 122.4(d), 40 CFR 122.44(d), WAC 173-201A-200(1)(d)(ii) (water quality-based, all affected States)
Phosphorus Management Plan	40 CFR 122.44(k) (best management practices)
Floating, Suspended or Submerged Matter	CWA Section 301(b)(1)(C), 40 CFR 122.44(d), IDAPA 58.01.02.200.05 (water quality-based)
E. Coli	CWA Section 301(b)(1)(C), 40 CFR 122.44(d), IDAPA 58.01.02.251.01 (water quality-based)
Chlorine	CWA 301(b)(1)(C), 40 CFR 122.44(d), IDAPA 58.01.02.210, IDAPA 58.01.02.060 (water quality-based, with mixing zone)
Ammonia (February – October)	CWA Section 301(b)(1)(C), 40 CFR 122.4(d), 40 CFR 122.44(d), WAC 173-201A-200(1)(d)(ii) (water quality-based, all affected States)
Ammonia (concentration, November – January)	CWA Section 402(o) (anti-backsliding)
Ammonia (mass, November – January)	40 CFR 122.45(f), 40 CFR 122.45(b)(1) (mass limits)
Lead	CWA Section 301(b)(1)(C), 40 CFR 122.4(d), 40 CFR 122.44(d), IDAPA 58.01.02.055.04, IDAPA 58.01.02.210 (water quality-based)
Zinc	CWA Section 301(b)(1)(C), 40 CFR 122.4(d), 40 CFR 122.44(d), IDAPA 58.01.02.055.04, IDAPA 58.01.02.210 (water quality-based)
Toxics Management Plan	40 CFR 122.44(k) (best management practices)

## Appendix D: Reasonable Potential Calculations

The following describes the process EPA has used to determine if the discharge authorized in the draft permit has the reasonable potential to cause or contribute to an excursion above Idaho's federally approved water quality standards for certain pollutants. EPA generally uses the process described in Section 3.3 of the *Technical Support Document for Water Quality-based Toxics Control* (EPA, 1991) to determine reasonable potential.

To determine if there is reasonable potential for the discharge to cause or contribute to an excursion above water quality criteria for a given pollutant, EPA compares the maximum projected receiving water concentration to the criteria for that pollutant. If the projected receiving water concentration exceeds the criteria, then the discharge has the reasonable potential to cause or contribute to excursions above water quality standards, and a water quality-based effluent limit must be included in the permit. This section discusses how the maximum projected receiving water concentration is determined.

### A. Mass Balance

For discharges to flowing water bodies, the maximum projected receiving water concentration is determined using the following mass balance equation:

$$C_d Q_d = C_e Q_e + C_u Q_u \quad (\text{Equation D-1})$$

where,

$C_d$  = Receiving water concentration downstream of the effluent discharge (that is, the concentration at the edge of the mixing zone)

$C_e$  = Maximum projected effluent concentration

$C_u$  = 95th percentile measured receiving water upstream concentration

$Q_d$  = Receiving water flow rate downstream of the effluent discharge =  $Q_e + Q_u$

$Q_e$  = Effluent flow rate (generally set equal to the design flow of the treatment plant per 40 CFR 122.45(b)(1)).

$Q_u$  = Receiving water low flow rate upstream of the discharge (e.g. 1Q10, 7Q10)

When the mass balance equation is solved for  $C_d$ , it becomes:

$$C_d = \frac{C_e Q_e + C_u Q_u}{Q_e + Q_u} \quad (\text{Equation D-2})$$

The above form of the equation is based on the assumption that the discharge is rapidly and completely mixed with the receiving stream and that 100% of the stream flow is available for mixing. However, the Idaho water quality standards generally restrict the percentage of the stream flow that may be allowed for dilution of the effluent. When the mixing zone uses less than 100% of the stream flow, the equation becomes:

$$C_d = \frac{C_e Q_e + C_u (Q_u \times MZ)}{Q_e + (Q_u \times MZ)} \quad (\text{Equation D-3})$$

In the above equation, MZ is the fraction of the receiving water flow available for dilution. The Idaho water quality standards generally limit mixing zones to 25% of the volume of the stream

flow (IDAPA 58.01.02.060). The MZ was generally set equal to 0.25 (25%) for the reasonable potential analysis. Exceptions include cadmium, lead, and zinc (because the receiving water is impaired for those parameters and cannot provide dilution of the effluent, therefore no mixing zone may be authorized for those parameters).

If a mixing zone is not allowed, dilution is not considered when projecting the receiving water concentration and,

$$C_d = C_e \quad (\text{Equation D-4})$$

The criteria for the metals of concern are expressed as dissolved metal. However, effluent limits for metals in NPDES permits must be expressed as total recoverable metal. The dissolved criterion must be converted to an equivalent total recoverable concentration by using a conversion factor, as shown in Equation D-5:

$$C_d = CF \times C_e \quad (\text{Equation D-5})$$

Equation D-3 can be simplified by introducing a “dilution factor,”

$$D = \frac{Q_e + 0.25 \times Q_u}{Q_e} \quad (\text{Equation D-6})$$

The dilution factors for the various seasons, for the reasonable potential analysis are shown in Table D-1, below:

<b>Table D-1: Dilution Factors</b>						
<b>Season or Parameter</b>	<b>Mixing Zone (% of critical flow)</b>	<b>Acute Dilution Factor (1Q10)</b>	<b>Chronic Dilution Factor (7Q10)</b>	<b>Chronic Ammonia Criterion Dilution Factor (30Q10)</b>	<b>Human Health Non-Carcinogen Dilution Factor (30Q5)</b>	<b>Human Health Carcinogen Dilution Factor (Harmonic Mean)</b>
Full Year	25%	N/A	N/A	N/A	17.2	67.2
July – September	25%	17.2	17.2	17.2	N/A	N/A
October – June	25%	12.8	34.3	42.0	N/A	N/A
Cadmium, lead, and zinc	No mixing zone (receiving water is impaired)					

After the dilution factor simplification, Equation D-2 becomes:

$$C_d = \frac{C_e - C_u}{D} + C_u \quad (\text{Equation D-7})$$

If the criterion is expressed as dissolved metal, the effluent concentrations are measured in total recoverable metal and must be converted to dissolved metal as shown in Equation D-8, which applies when a mixing zone may be granted for a metal with criteria expressed as dissolved metal.

$$C_d = \left[ \frac{CF \times C_e - C_u}{D} \right] + C_u \quad (\text{Equation D-8})$$

In equation D-8,  $C_e$  is expressed as total recoverable metal and  $C_d$  and  $C_u$  are expressed as dissolved metal. Equations D-5, D-7, and D-8 are the forms of the mass balance equation which were used to determine reasonable potential and calculate wasteload allocations.

## **B. Maximum Projected Effluent Concentration**

### ***Parameters with Water Quality-based Effluent Limits in the 1999 Permit***

For parameters that were subject to water quality-based effluent limits in the 1999 permit and for which effluent are not necessary to meet Washington's water quality standards (copper, lead, zinc, and winter ammonia) EPA has used the maximum daily effluent limits in the 1999 permit as the maximum projected effluent concentrations. This allows EPA to determine if the effluent limits in the 1999 permit are stringent enough to prevent the discharge from causing or contributing to excursions above water quality standards for these pollutants. If a discharge at the maximum daily limits in the 1999 permit did not have the reasonable potential to cause or contribute to excursions above water quality standards, EPA retained the 1999 effluent limits under the anti-backsliding provisions of the Act (Section 402(o)).

Although chlorine was subject to water quality-based effluent limits in the 1999 permit, EPA has used effluent data to calculate a maximum projected effluent concentration for chlorine, because the facility now uses ultraviolet disinfection, and the effluent limits in the 1999 permit therefore may not be representative of the current concentrations of chlorine in the discharge. The use of actual effluent data also allows EPA to determine if the effluent concentrations of chlorine change based on whether chlorine is used in the treatment process, and, if so, if that change affects the reasonable potential determination. Also, an exception to the anti-backsliding provisions of the Act is applicable to chlorine, because of the switch to ultraviolet disinfection (material and substantial alterations or additions, CWA Section 402(o)(2)(A)).

As shown in Table 2, below, the Post Falls facility has the reasonable potential to cause or contribute to excursions above water quality standards if and only if chlorine is used in the treatment process.

### ***Ammonia Limits Necessary to Meet Washington Water Quality Standards***

EPA has determined that, independent of Idaho's water quality standards, effluent limits for ammonia are necessary from February – October to ensure compliance with Washington's water quality standards for DO (see Appendix B). Therefore, EPA has used the average weekly effluent limit that is necessary to meet Washington's water quality standards as the maximum projected effluent concentration. A discharge of ammonia at the average weekly effluent limits that are necessary to meet Washington's water quality standards would will not cause or contribute to excursions above Idaho's water quality standards for ammonia. Therefore, from February – October, it is not necessary to establish effluent limits in addition to or more stringent than those necessary to meet Washington's water quality standards.

### ***Other Parameters***

To calculate the maximum projected effluent concentration for parameters not specifically discussed above, EPA has used the procedure described in section 3.3 of the TSD, "Determining the Need for Permit Limits with Effluent Monitoring Data." In this procedure, the 99<sup>th</sup> percentile

of the effluent data is the maximum projected effluent concentration in the mass balance equation.

Since there are a limited number of data points available in most cases, the 99<sup>th</sup> percentile is calculated by multiplying the maximum reported effluent concentration by a “reasonable potential multiplier” (RPM). The RPM is the ratio of the 99<sup>th</sup> percentile concentration to the maximum reported effluent concentration. The RPM is calculated from the coefficient of variation (CV) of the data and the number of data points. The CV is defined as the ratio of the standard deviation of the data set to the mean, but when fewer than 10 data points are available, the TSD recommends making the assumption that the CV is equal to 0.6.

In addition to Section 3.3 of the TSD, the procedures for calculating a maximum projected effluent concentration from effluent data are described in detail in Appendix D of the fact sheet dated February 16, 2007. The results of the reasonable potential analysis are described below.

### Cadmium

EPA used the 95<sup>th</sup> percentile effluent concentration for cadmium, instead of the more conservative 99<sup>th</sup> percentile, which was used for other parameters. EPA believes this is appropriate for the following reasons.

First, the maximum measured effluent concentration of cadmium (0.79 µg/L, measured in July 2010) is more than twice the next-highest concentration (0.35 µg/L, measured in April 2011), is eight standard deviations above the mean, and is a statistical outlier at a significance level of 1%. Therefore, an effluent cadmium concentration of similar magnitude is unlikely to be observed again in the future. Furthermore, effluent cadmium concentrations measured after April 2010 are statistically significantly higher than those measured before April 2010. The highest effluent cadmium concentration measured between January 2004 and April 2010 is only 0.12 µg/L (measured in May 2008).

In order to investigate the recent apparent increase on cadmium concentrations, the City of Post Falls sent split effluent samples to two alternative laboratories in addition to the laboratory that the City had been using for cadmium measurements for the past several years, in August 2011. In these split samples, the median cadmium concentration measured by the City’s usual laboratory was 0.18 µg/L, which is six times the median concentration measured in the split samples by the two alternative laboratories (0.03 µg/L). The median concentration measured by the two alternative laboratories in August 2011 was close to the median concentration measured from January 2004 through April 2010 (0.017 µg/L). The difference between the measurements of the August 2011 split samples from the usual laboratory and the two alternative laboratories is statistically significant ( $P = 0.0385$ ). This information suggests that cadmium results measured by the City’s usual lab after April 2010 may be artificially high.

In Section 3.3.2, the TSD states that, “although (the 99<sup>th</sup> percentile) does represent a measure of the upper bound of an effluent distribution, other percentiles could be selected by a regulatory agency.” As explained above, the cadmium concentrations measured after April 2010 may be artificially high. Although there is not enough information to justify discarding the cadmium results measured after April 2010 from the reasonable potential analysis, EPA believes it is appropriate to use a lower (i.e., less conservative) effluent percentile value in the reasonable potential analysis for cadmium, because there is conservatism inherent in including the statistical outlier (0.79 µg/L) as well as other high values measured after April 2010 in the reasonable

potential analysis. The TSD provides a table of reasonable potential multipliers for both the 95<sup>th</sup> and 99<sup>th</sup> percentiles (Tables 3-1 and 3-2). Therefore, EPA believes, in this case, it is appropriate to use the 95<sup>th</sup> percentile effluent concentration as the maximum projected effluent concentration for cadmium, instead of the 99<sup>th</sup> percentile.

**C. Results**

Tables 2 and 3, below, summarize the reasonable potential calculations.

**D. References**

EPA. 1991. *Technical Support Document for Water Quality-based Toxics Control*. US Environmental Protection Agency, Office of Water, EPA/505/2-90-001.

Table 2: Reasonable Potential Calculations (Except Cadmium)

Effluent Percentile value	99%			State Water Quality Standard		Max concentration at edge of...												
	Metal Criteria Translator as decimal	Metal Criteria Translator as decimal	Ambient Concentration (metals as dissolved)	Acute ug/L	Chronic ug/L	Acute Mixing Zone ug/L	Chronic Mixing Zone ug/L	LIMIT REQ'D?		Max effluent conc. measured (metals as total recoverable)	Coeff Variation	s	# of samples	Multiplier	Acute Di'n Factor	Chronic Di'n Factor		
Parameter	Acute	Chronic	ug/L	ug/L	ug/L	ug/L	ug/L		Pn	ug/L	CV		n				COMMENTS	
Ammonia, Prev. Lim. (Oct - June)	1.00	1.00	0.1000	6.75	2.38	3.18	2.28	NO	N/A	91.7	N/A	N/A	N/A	1.00	29.8	42.0	25% MZ	
Ammonia, WA Std AWL (July - Sept)	1.00	1.00	0.1000	6.75	1.42	4.90	0.83	NO	N/A	12.66	N/A	N/A	N/A	1.00	2.62	17.16	25% MZ chronic, 2.5% MZ acute	
Ammonia, WA Std AWL (Oct - June)	1.00	1.00	0.1000	6.75	2.38	3.34	0.40	NO	N/A	12.66	N/A	N/A	N/A	1.00	3.9	42.0	25% MZ chronic, 2.5% MZ acute	
Butylbenzyl phthalate	1.00	1.00			1500		1.08	NO	0.010	1.40	0.60	0.55	1	13.20		17.16	25% MZ	
Chlorine (July - Sept)	1.00	1.00		19.0000	11.0000	4.57	4.57	NO	0.997	100	0.56	0.52	1749.00	0.78	17.16	17.16	25% MZ, CI not used	
Chlorine (Oct - June)	1.00	1.00		19.0000	11.0000	2.64	2.29	NO	0.997	100	0.56	0.52	1749.00	0.78	29.76	34.29	25% MZ, CI not used	
Chlorine (July - Sept)	1.00	1.00		19.0000	11.0000	22.85	22.85	YES	0.957	295	0.50	0.47	106.00	1.33	17.16	17.16	25% MZ, CI used	
Chlorine (Oct - June)	1.00	1.00		19.0000	11.0000	13.17	11.43	YES	0.957	295	0.50	0.47	106.00	1.33	29.76	34.29	25% MZ, CI used	
Copper (July - Sept, Prev. Conc. Lim)	0.96	0.96		4.6090	3.4719	1.55	1.55	NO	N/A	27.70	N/A	N/A	N/A	1.00	17.16	17.16	25% MZ	
Copper (Oct - June)	0.96	0.96		4.6090	3.4719	0.29	0.25	NO	0.936	7.34	0.26	0.25	70	1.23	29.76	34.29	25% MZ	
Diethyl phthalate	1.00	1.00			17000		1.08	NO	0.010	1.40	0.60	0.55	1	13.20		17.16	25% MZ	
Di-N-butyl phthalate	1.00	1.00			2000		1.23	NO	0.010	1.60	0.60	0.55	1	13.20		17.16	25% MZ	
Lead (EOP, Prev. Lim.)	0.79	0.79		59.3	2.3	3.01	3.01	YES	N/A	3.79	N/A	N/A	N/A	1.00	1	1	RW Impaired; no MZ	
Nitrate + Nitrite	1.00	1.00	0.0760		10		1.55	NO	0.924	23.56	0.08	0.08	58	1.07		17.16	25% MZ	
Phenol	1.00	1.00			21000		6.92	NO	0.010	9.00	0.60	0.55	1	13.20		17.16	25% MZ	
TSS (TBEL)	1.00	1.00	4.0000	25.0000	25.0000	6.39	6.39	NO	N/A	45.00	0.60	0.55	N/A	1.00	17.16	17.16	25% MZ	
WET	1.00	1.00		3.0000	1.0000	0.19	0.19	NO	0.750	2.00	0.31	0.30	16	1.64	17.16	17.16	25% MZ	
Zinc (EOP, prev. lim.)	0.98	0.99		115	116	112	113	NO	N/A	115	N/A	N/A	N/A	1.00	1	1	RW Impaired; no MZ	

Table 3: Reasonable Potential Calculations for Cadmium

Effluent Percentile value	95%																	



## Appendix E: WQBEL Calculations – Acute and Chronic Numeric Aquatic Life Criteria

The discussion explains how water quality-based effluent limits (WQBELs) in the draft permit were calculated based on Idaho's numeric water quality criteria for aquatic life uses. The calculations for all WQBELs based on aquatic life criteria are summarized in Table 1, below.

### A. Calculate the Wasteload Allocations (WLAs)

Wasteload allocations (WLAs) are calculated using the same mass balance equations used to calculate the concentration of the pollutant at the edge of the mixing zone in the reasonable potential analysis. These equations are explained in Appendix D. To calculate the wasteload allocations, the downstream concentration ( $C_d$ ) is set equal to the acute or chronic water quality criterion and the equation is solved for the effluent concentration ( $C_e$ ). The calculated  $C_e$  is the acute or chronic WLA. Equation D-6 is rearranged to solve for the WLA, becoming:

$$C_e = \text{WLA} = D \times (C_d - C_u) + C_u \quad (\text{Equation E-1})$$

Idaho's water quality criteria for some metals are expressed as the dissolved fraction, but the Federal regulation at 40 CFR 122.45(c) requires that effluent limits be expressed as total recoverable metal. Therefore, EPA must calculate a wasteload allocation in total recoverable metal that will be protective of the dissolved criterion. This is accomplished by dividing the WLA expressed as dissolved by the criteria translator (CT), as shown in equation E-2.

$$C_e = \text{WLA} = \frac{D \times (C_d - C_u) + C_u}{\text{CT}} \quad (\text{Equation E-2})$$

Or, if no mixing zone is allowed, for metals with criteria expressed as the dissolved fraction:

$$C_e = \text{WLA} = C_d \div \text{CT} \quad (\text{Equation E-3})$$

### Mixing Zones

Mixing zones for effluent limit calculations are the same as those used for the reasonable potential analysis and described in Appendix D.

### B. Basis for Expressing Effluent Limits for Toxic Parameters as Average Monthly and Maximum Daily Limits

In general, effluent limits for POTWs must be expressed as average monthly and average weekly limits (40 CFR 122.45(d)(2)). In order to prevent acute toxicity to aquatic life, the Technical Support Document for Water Quality-based Toxics Control ("TSD") recommends that effluent limits for pollutants which may be toxic to aquatic life be expressed as average monthly and maximum daily limits, because an average weekly limit has an averaging period that is too long to ensure that acute toxicity is prevented (see TSD at section 5.2.3). Therefore, effluent limits for total residual chlorine, silver, zinc and winter ammonia are therefore expressed as average monthly and maximum daily limits, based on the recommendations of Section 5.2.3 of the TSD.

**C. Calculating the Average Monthly and Maximum Daily Effluent Limits**

The statistical procedures for calculating of average monthly and maximum daily effluent limits from the wasteload allocations are described in Section 5.4 of the TSD and in Appendix G of the fact sheet dated February 16, 2007.

Although the reasonable potential analysis showed that a discharge at the 1999 permit's maximum daily limits for lead could cause or contribute to excursions above water quality standards for those parameters, when EPA re-calculated the effluent limits for lead using the procedure described below, the re-calculated maximum daily effluent limit for lead was less stringent than the maximum daily limit in the 1999 permit. Therefore, the maximum daily lead effluent limits in the 1999 permit have been continued forward in accordance with the anti-backsliding provisions of the Clean Water Act and the State of Idaho's antidegradation policy.

**D. Results**

The results of the effluent limit calculations are summarized in Table 1, on the following page.

The lead concentration effluent limits calculated in Table 1, below, are less stringent than the limits in the 1999 permit. Therefore, the 1999 permit's concentration limits for lead have been continued forward under the anti-backsliding provisions of the Clean Water Act.

Table 1: Effluent Limit Calculations

Statistical variables for permit limit calculation		<div>Dilution (Dil'n) factor is the inverse of the percent effluent concentration at the edge of the acute or chronic mixing zone.</div>																			
LTA Probability Basis	99%																				
MDL Probability Basis	99%																				
AML Probability Basis	95%																				
Permit Limit Calculation Summary												Waste Load Allocation (WLA) and Long Term Average (LTA) Calculations									
PARAMETER	Acute Dil'n Factor	Chronic Dil'n Factor	Metal Criteria Translator	Metal Criteria Translator	Ambient Concentration	Water Quality Standard Acute	Water Quality Standard Chronic	Average Monthly Limit (AML)	Maximum Daily Limit (MDL)	Comments	WLA Acute	WLA Chronic	LTA Acute	LTA Chronic	Limiting LTA	Coeff. Var. (CV)	# of Samples per Month				
			Acute	Chronic	ug/L	ug/L	ug/L	ug/L	ug/L		ug/L	ug/L	ug/L	ug/L	ug/L	decimal	n				
Chlorine (July-Sep)	17.16	17.16	1.00	1.00		19.00	11.00	127	294	25% MZ	326	189	122	110	110	0.498	30.00	1.00			
Chlorine (Oct-June)	29.76	34.29	1.00	1.00		19.00	11.00	244	565	25% MZ	565	377	211.3	219.6	211.3	0.498	30.00	1.00			
Lead (EOP)	1.00	1.00	0.79	0.79		59.29	2.31	2.3	4.9	End-of-pipe	74.6	2.91	21.3	1.41	1.41	0.69	4.00	1.00			

## Appendix F: Effluent Limit Calculations for pH

The following table demonstrates how appropriate effluent limitations were determined for pH.

<b>Table F-1: Effluent Limit Calculations for the Low pH Critical Condition</b>		
INPUT	Oct. – June	July – Sept.
DILUTION FACTOR AT MIXING ZONE BOUNDARY	29.8	17.2
UPSTREAM/BACKGROUND CHARACTERISTICS		
Temperature (deg C):	14.5	25.0
pH:	6.60	6.60
Alkalinity (mg CaCO <sub>3</sub> /L):	19.2	19.2
EFFLUENT CHARACTERISTICS		
Temperature (deg C):	16.0	16.0
<b>pH:</b>	<b>6.3</b>	<b>6.4</b>
Alkalinity (mg CaCO <sub>3</sub> /L):	133	133
OUTPUT		
1. IONIZATION CONSTANTS		
Upstream/Background pKa:	6.42	6.35
Effluent pKa:	6.41	6.41
2. IONIZATION FRACTIONS		
Upstream/Background Ionization Fraction:	0.60	0.64
Effluent Ionization Fraction:	0.44	0.49
3. TOTAL INORGANIC CARBON		
Upstream/Background Total Inorganic Carbon (mg CaCO <sub>3</sub> /L):	32.01	30.00
Effluent Total Inorganic Carbon (mg CaCO <sub>3</sub> /L):	305.10	269.70
CONDITIONS AT MIXING ZONE BOUNDARY		
Temperature (deg C):	14.55	24.48
Alkalinity (mg CaCO <sub>3</sub> /L):	23.02	25.83
Total Inorganic Carbon (mg CaCO <sub>3</sub> /L):	41.18	43.97
pKa:	6.42	6.35
<b>pH at Mixing Zone Boundary:</b>	<b>6.53</b>	<b>6.51</b>

## **Appendix G: Compliance Schedules and Interim Limits for New Water Quality-based Effluent Limits**

### **A. Overview**

In order to establish a compliance schedule in an NPDES permit, the permitting authority must make a reasonable finding that the permittee cannot comply with the new water quality-based effluent limit immediately upon the effective date of the final permit (see memorandum from Jim Hanlon to Alexis Strauss dated May 10, 2007). Compliance schedules may only be allowed if the State's water quality standards or implementing regulations allow for compliance schedules (see *In The Matter of Star-Kist Caribe, Inc.*, 3 E.A.D. 172, 175, 177 (1990)). The State of Idaho has a compliance schedule authorizing provision which reads, "discharge permits for point sources may incorporate compliance schedules which allow a discharger to phase in, over time, compliance with water quality-based effluent limitations when new limitations are in the permit for the first time" (IDAPA 58.01.02.400.03). The State of Idaho has authorized compliance schedules for some of the new water quality-based effluent limits in the City of Post Falls permit in its draft Clean Water Act Section 401 certification of this permit.

EPA has evaluated the historic performance of the Post Falls wastewater treatment plant to determine if the City could immediately comply with the new water quality-based effluent limits proposed in the draft permit. For those effluent limits that cannot be achieved immediately on the effective date of the final permit, the compliance schedule must comply with the regulatory requirement that compliance be achieved as soon as possible (40 CFR 122.47(a)(1)). EPA has determined that the compliance schedules proposed in the draft permit require compliance as soon as possible, as explained below.

### **B. Immediate Achievability**

In general, for each parameter for which a new water quality-based effluent limit is proposed, EPA used two different methods to quantify the facility's current performance. The current performance was compared to the proposed new water quality-based effluent limits to determine if the facility could comply with the new water quality-based effluent limits immediately upon the effective date of the final permit. The methods used to evaluate the facility's current performance are described below.

In general, if the facility's current performance, as quantified by the two methods described below, showed that the facility could comply with the new water quality-based effluent limits immediately upon the effective date of the final permit, then no compliance schedule has been proposed in the draft permit. If effluent data demonstrate that the facility cannot comply with the effluent limits immediately upon the effective date of the final permit, then a schedule of compliance is appropriate and has been proposed in the draft permit. In addition to the facility's current performance, EPA has also considered the treatment plant's design characteristics and the performance of other facilities of similar design. If the Post Falls facility's treatment processes would allow for immediate compliance with new water quality-based effluent limits, then no compliance schedule has been proposed in the draft permit, even if historical effluent data do not indicate immediate achievability.

***Performance-based Effluent Limit Spreadsheet Method***

This spreadsheet calculates performance-based effluent limits based on historical effluent data and the required sampling frequency. The spreadsheet is based upon the procedures of Appendix E of the *Technical Support Document for Water Quality-based Toxics Control* (EPA 1991).

***Percentile Method***

When individual sample results are available, the expected maximum monthly, weekly, and daily loadings or concentrations can be represented by percentiles. The expected maximum monthly average concentration or loading is that which can be achieved 11/12ths (92%) of the time, and the expected maximum weekly average and maximum daily concentration or loading is that which can be achieved 51/52nds (98%) and 364/365ths (99.7%) of the time, respectively. EPA used this method of quantifying performance in the *Municipal Nutrient Removal Technologies Reference Document* (EPA 2008). If less than 365 data points were available, the maximum individual sample was used for comparison with a proposed water quality-based maximum daily limit.

***Results of Effluent Data Analysis***

The results of the analysis are summarized in Table 1, below.

Table 1: Comparison of New Water Quality-based Effluent Limits to Historic Performance								
New Water Quality-based Effluent Limit Parameter, Season, and Units	Proposed Limits		Current Performance				EPA Evaluation of Oxidation Ditches for Nutrient Removal	Limits Achievable Immediately?
	Avg. Monthly Limit	Max. Daily or Avg. Weekly Limit	PERFORMLIM Spreadsheet		Percentiles		Max. Month	
			Max. Month	Max. Day/Week	Max. Month	Max. Day/Week		
CBOD <sub>5</sub> , February – October (lb/day)	334	534	122	170	173	263	676	YES
Ammonia, February – October (lb/day)	334	528	2.3	4.0	2.6	17.6	169	YES
Ammonia, July – September (mg/L)	8.0	12.7	0.11	0.20	0.13	0.88	5.0	YES
Chlorine, July – September (µg/L)	127	294	120	382	145	295	N/A	YES (see below)
Chlorine, October – June (µg/L)	244	565					N/A	YES
Notes:								
1. The maximum daily effluent limits for lead and the average monthly loading (lb/day) limits are identical to those in the prior (1999) permit. Thus they are not new limits and thus no compliance schedule may be authorized for the maximum daily lead effluent limits or the average monthly lead loading limits.								

***Discussion of Results******CBOD<sub>5</sub>***

According to EPA's Evaluation of Oxidation Ditches for Nutrient Removal (EPA 832-R-92-003, September 1992), which evaluated the performance of 17 POTWs using oxidation ditches for

treatment, facilities of this type can achieve an average monthly effluent BOD<sub>5</sub> concentration of 20 mg/L 100% of the time from May – October and 99% of the time from November – April. A discharge of 20 mg/L of CBOD<sub>5</sub> is equivalent to a load of 676 lb/day at Post Falls' maximum effluent flow rate of 4.05 mgd.

However, as shown in Table 1, above, both the percentile and performance-based limit spreadsheet calculations show that the Post Falls facility can comply with the new water quality-based effluent limits for CBOD<sub>5</sub> immediately upon the effective date of the final permit. The Post Falls facility is evidently performing better than a typical oxidation ditch POTW, in terms of CBOD<sub>5</sub> removal. Therefore, no compliance schedule may be authorized for the new water quality-based CBOD<sub>5</sub> effluent limits.

#### Ammonia

As shown in Table 1, above, both the percentile and performance-based spreadsheet calculations indicate that the Post Falls facility can comply with the average monthly and average weekly concentration and load limits for ammonia that are proposed in the draft permit immediately upon the effective date of the final permit.

Furthermore, according to EPA's *Evaluation of Oxidation Ditches for Nutrient Removal*, POTWs using oxidation ditches for treatment can achieve a monthly average ammonia concentration of 5.0 mg/L 100 % of the time from May – October and 98% of the time from November – April (Page FS-3). This is less than the proposed average monthly concentration limit of 8.0 mg/L, which applies from July – September.

A discharge of 5.0 mg/L of ammonia is equivalent to a load of 169 lb/day at Post Falls' maximum effluent flow rate of 4.05 mgd, and 209 lb/day at the design flow rate of 5.0 mgd. The proposed new water quality-based average monthly effluent limit for ammonia is 334 lb/day. Therefore, the Post Falls facility can comply with the new water quality-based ammonia limits proposed in the draft permit immediately upon the effective date of the final permit and no compliance schedule may be authorized.

#### Chlorine

No compliance schedule is proposed for the new water quality-based effluent limits for total residual chlorine. While effluent data alone indicate that the facility may have difficulty meeting the new water quality-based effluent limits from July – September, the facility is equipped with ultraviolet disinfection, with chlorination and dechlorination as a backup. The effluent limits apply only when chlorine is used within the treatment facility. Dechlorination will allow the City to meet the new water quality-based effluent limits for chlorine year-round immediately upon the effective date of the final permit. In addition, the chlorine limits are generally less stringent than the effluent limits in the prior permit. Therefore, no compliance schedule is necessary for chlorine.

#### Phosphorus

The effluent limit for total phosphorus is a seasonal average of 3.19 lb/day. The current average phosphorus loading is 10.8 lb/day. Therefore the City cannot comply with the new water quality-based seasonal average effluent limit for total phosphorus immediately upon the effective date of the final permit and a compliance schedule is appropriate for this effluent limit.

### Summary

The permittee can comply with all of the new water quality-based effluent limits in the draft permit, except for the new phosphorus limits and some of the new ammonia limits. Therefore, a compliance schedule is proposed for the new water quality-based phosphorus limits and the new water quality-based ammonia limits except for the average monthly and maximum daily ammonia loading limits for the month of October.

### ***Interim Limits***

#### Basis for Interim Limits

The federal regulation 40 CFR 122.47 states that "...if a permit establishes a schedule of compliance which exceeds 1 year from the date of permit issuance, the schedule shall set forth interim requirements and the dates for their achievement." The federal regulation 40 CFR 122.44(l)(1) states that "...when a permit is renewed or reissued, interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit."

Therefore, EPA has proposed interim effluent limits in the draft permit, which apply during the term of the compliance schedule, in order to ensure that the reissued permit does not authorize the discharge of ammonia or phosphorus in greater amounts than authorized by the previous permit, during the term of the compliance schedule.

#### Total Phosphorus

The prior permit includes a 70% average monthly removal rate effluent limit for total phosphorus, which applies from March 1<sup>st</sup> through October 31<sup>st</sup>. Thus, the prior permit has average monthly limits expressed in terms of removal rate, but it lacks average weekly limits and limits expressed in terms of mass, both of which are required by federal regulations (40 CFR 122.45(d)(2), 122.45(f)). Thus, EPA has established mass limits and average weekly limits in order to comply with federal regulations.

The interim average monthly mass limit was calculated as follows. First, the removal rate was converted to an equivalent effluent concentration. The 92<sup>nd</sup> percentile influent total phosphorus concentration (which is an estimate of the maximum monthly average influent concentration) from 2006 – 2011 was 7.87 mg/L. The prior permit would have allowed an effluent concentration that was 30% of the influent concentration; 30% of 7.87 mg/L is 2.36 mg/L. The design flow of the City of Post Falls POTW at the time the prior permit was issued was 3.48 mgd. A discharge of phosphorus at 2.36 mg/L, at 3.48 mgd, is equivalent to a load of 68.5 lb/day. This is the load of phosphorus that was authorized to be discharged under the 1999 permit.

In order to ensure compliance with federal regulations requiring that, in general, effluent limits for POTWs are stated as average monthly and average weekly limits, EPA has also established interim average weekly TP limits based on the average monthly limits, and a ratio that accounts for effluent variability within a month. EPA has used the same ratio as the ratio between the technology-based average monthly and average weekly CBOD<sub>5</sub> limits (1.6:1). EPA believes this ratio is representative of typical effluent variability for POTWs. Thus, the average weekly TP limit is 110 lb/day.



The prior permit's phosphorus limits applied from March 1<sup>st</sup> through October 31<sup>st</sup> each year. The interim effluent limits for total phosphorus apply from February 1<sup>st</sup> through October 31<sup>st</sup> each year, which is the same season during which the final TP effluent limits will apply. Modeling has shown that discharges of TP at any time during this season can affect dissolved oxygen concentrations in Lake Spokane.

### C. As Soon as Possible

*To be added following receipt of the draft Clean Water Act Section 401 Certification.*

### D. References

EPA. 1991. *Technical Support Document for Water Quality-based Toxics Control*. US Environmental Protection Agency, Office of Water, EPA/505/2-90-001. March 1991.

EPA. 1992. *Evaluation of Oxidation Ditches for Nutrient Removal*. US Environmental Protection Agency. Office of Wastewater Enforcement and Compliance. EPA 832-R-92-003. September 1992.

EPA. 2008. *Municipal Nutrient Removal Technologies Reference Document*. US Environmental Protection Agency. Office of Wastewater Management, Municipal Support Division, Municipal Technology Branch. EPA 832-R-08-006. September 2008.